

**PURCHASING
AND MATERIALS
MANAGEMENT**



**City of Myrtle Beach
SOUTH CAROLINA**

**(843) 918-2170
FAX: (843) 918-2182
www.cityofmyrtlebeach.com**

Addendum 02

May 25, 2023

IFB 23-B0048

Myrtle Beach World War II Memorial

The purpose of this Addendum 02 to IFB 23-B0048 for Myrtle Beach World War II Memorial dated May 25, 2023, and previously amended on May 11, 2023 is to provide some modifications to the bid documents and updated/additional drawings.

- Section 004113 – Stipulated Sum (Single-Prime Contract) of the bid documents shall be replaced with the updated Bid Form. The updated Bid Form has been attached and is hereby made a part of this addendum.
- Section 004113 – Note 8 revised to read: “The City of Myrtle Beach will be installing a new irrigation water meter and tap adjacent to Farrow Parkway, south of the WWII Memorial. The Contractor shall be responsible for installing a new 1” PVC irrigation water main from the new water meter location to the northwest corner of the WWII Memorial plaza as shown on the plans. The Contractor shall install PVC sleeves under all existing pathway crossings.”
- Section 004113 – Note 10 language added to read: “The Contractor shall also be responsible for the installation/placement of the sculpture when it is delivered to the site.”
- Sheet C1.03 of the Lighting Plan
 - o Note 3 revised to read: “Contractor shall install 2in schedule 80 conduit with conductors from new meter base pedestal to the new electrical panel located on back of wall.”
 - o Note 2 revised to read: “All work shall be completed by a licensed electrician. All work shall be inspected by the City of Myrtle Beach and State of South Carolina.”
 - o Note 16 revised to read: “All site lighting circuits shall be controlled with timer and photocell (Circuits #1-5). GFCI Receptacles are to be fed from breakers for uninterrupted services (Circuits #6-8).”
 - o Electrical General Notes language added to read: “Conductors for line voltage and low voltage shall be in separate conduits per National Electrical Code and all other applicable codes and standards.”
 - o Luminaire Fixture Schedule Notes revised as shown on the updated Plan Sheet C1.03 that has been attached and is hereby made a part of this addendum.
 - o Additional language added to Luminaire Fixture Schedule Notes: 6; to include: light fixtures type B, C, and F are to be connected/controlled by Qtran

Transformer. Light fixture type E shall be connected/controlled by LuxR
Transformer. All transformers and connectors shall be exterior location listed.

- Sheet C2.01 Wall Details replaced with the updated sheet that is attached and is hereby made a part of this addendum.
- Sheet C2.04 Pergola Details replaced with the updated sheet that is attached and is hereby made a part of this addendum.
- Sheet C2.05 Misc Detail addition of bronze plaque layout/details as shown on the updated sheet that is attached and is hereby made a part of this addendum.
- Sheet L1.03: Irrigation
 - o Replace with updated sheet that is attached and is hereby made a part of this addendum. Replacement sheet includes additional sleeves, irrigation zones, and modifications to irrigation rotors, spray heads, and drip lines.
 - o Additional layout detail for 1" water main from location of City installed water meter to the World War II Memorial, as shown on the replacement sheet.

All bid must be received no later than 2:00P.M. on June 1, 2023. No electronic bids will be accepted. The City is not responsible for late or misdirected mail.

Please send in your bid in a sealed envelope to the address below:

City of Myrtle Beach
3231 Mr. Joe White Avenue
Myrtle Beach, SC 29577
Attn: Purchasing Division/Brandon Hancock

