

## ADDENDUM NO. I

BID NUMBER: 305842

BID TITLE: 36" Dezurik Knife Gate Valves

DEPARTMENT: Waste Resources Division

DATE OF ADDENDUM: March 19, 2020

ORIGINAL BID DUE DATE: March 19, 2020

ORIGINAL BID DUE TIME: 2:00 p.m., e.s.t.

**REVISED BID DUE DATE: April 22, 2020**

**REVISED BID DUE TIME: 2:00p.m., e.s.t.**

**REASON: DEADLINE HAS BEEN EXTENDED & ANSWERS TO QUESTIONS:**

**The bid opening has been extended until Wednesday, April 22, 2020**

Q. In the specifications under 2.1 states: "The drawing is a part of these specifications" We could not locate, can you please provide?

*A. Please see attachment below.*

Q. Under type of business classifications u list six types are any of these more important than the other or do they hold equal weight in the bidding process ?

*A. The business classifications do not hold any weight in the bidding process.*

(SIGNED): \_\_\_\_\_(DATE):\_\_\_\_\_

(COMPANY): \_\_\_\_\_

**Sign one (1) copy of this page and return it with your bid**, or separately and clearly labelled only if your bid has already been submitted to the Purchasing Department. Mail to Purchasing Dept., Attn: A Berkowitz, 101 E. 11th Street, Suite G-13, Chattanooga, TN 37402

**Retain a copy for your file.**

No.	PART NAME
A	VALVE
B	CONNECTING PARTS

- NOTE:
- VALVE IS SHOWN IN CLOSED POSITION.
  - VALVES ORDERED WITH THRU BOLTING HAVE ALL HOLES, EXCEPT THOSE THAT ARE BLIND TAPPED, DRILLED TO ANSI STANDARDS CLASS 125 & 150.
  - DRAWING SHOWS FLANGES TAPPED FOR USE WITH ANSI FLANGES, FOR USE WITH OTHER THAN ANSI FLANGES SEE A52587.
  - INSTALL THE VALVE WITH THE HIGHER PRESSURE AGAINST THE SIDE OPPOSITE THE SEAT WHEN THE VALVE IS CLOSED; EXCEPT AT THE BOTTOM OF DRY MATERIAL STORAGE VESSELS WHERE THE VALVE SHOULD BE INSTALLED WITH THE SEAT UPWARD.
  - VALVE MUST INSTALLED WITH THE GATE IN THE VERTICAL UPRIGHT POSITION.

