



**PURCHASING
AND MATERIALS
MANAGEMENT**

**City of Myrtle Beach
SOUTH CAROLINA**

**(843) 918-2170
FAX: (843) 918-2182
www.cityofmyrtlebeach.com**

**Addendum #01
July 23, 2018
IFB 19-B0006
Concrete Pad**

The purpose of this Addendum #01 to IFB 19-B0006 for a Concrete Pad, dated July 16, 2018, is to update the measurements and specifications of the project.

- The dimensions of the pad will be 32 feet by 40 feet.
- Contractor will be responsible for digging out and pouring in concrete so that it is level and in line with the existing grade.
- Pad to be poured up to fence posts. Concrete to have a broom finish.
- Wall weight will be approximately 500 pounds. No other structures will be placed on the pad, therefore base and fiber will not be necessary.
- Hours for work completion will be Monday through Friday, from 7:00AM to 5:00PM.

Bids will be received until 2:30PM on Monday, July 30, 2018.

Please send in your sealed bid to the address below:

City of Myrtle Beach
3231 Mr. Joe White Avenue
Myrtle Beach, SC 29577
Attn: Purchasing Division/Ann Sowers

If you have any questions, please don't hesitate to call to the undersigned below.

Thank-you,
City of Myrtle Beach
Ann Sowers/Procurement Office/Buyer
Email: asowers@cityofmyrtlebeach.com