

ADDENDUM #1 Bid #19-039
HVAC System at the Aquadome
Issued 8/22/2019

A duct smoke detector shall be installed in accordance with NFPA 90A on the supply side of the air handler including an annunciator.

You must acknowledge receipt of this bid in your sealed bid submission.

Company

Name

Signature