



**CITY OF CALLAWAY
PUBLIC WORKS FENCING PROJECT
BID NO.: PW2024-11**

ADDENDUM #3

Date Issued: June 10, 2024

This addendum is being released to address the following questions.

1. For the chain link fabric will Black Vinyl 2B 2" x 8ga. Finish(9ga. Core) x 72" Fused Bonded w/Salvage Knuckle/Twist be acceptable. Fence Detail Note just states Black Fused Bonded Vinyl Coated. **Yes.**
 2. Fence Detail Notes states Corner, End, and Pull Post to be 2-7/8". What is the diameter of the intermediate post? **2"**
 3. Addendum 2 question was answered regarding barbwire wire. My question is does the barbwire have to have vinyl coating or just be galvanized. vinyl coated. Does barbwire need to be 12.5ga. Class 3. If not, please specify. **Yes.**
 4. There are no framework weights called out. Does material need to be Schedule 40 yes. or will SS-40 be acceptable. Does material need to be Domestic (Buy American) **No.**
 5. Please see attached snip for the called out 14' existing gate opening. Please clarify opening it appears to only be around 6ft wide and to be a Roll Gate. Please confirm if this is correct or needs to be 6'+1H x 14'W single track aluminum cantilever slide gate. If it needs to be a Roll Gate will pad lock be required or supplied by others. **Replace existing gates as they exist in size.**
 6. Addendum #2 question and answer #2. Referred to the 20ft gates as roll gates which are different from cantilever slide gates. Please confirm the two 20ft gates that we are replacing are to be 6'+1H x 20'W Black Single Track Aluminum Cantilever Slide Gates. **Replace existing gates with same type gates.**
 7. Fence detail on sheet #3 calls out for a 3/8" x 11' Truss Rod Only, typically this is accompanied with a brace rail, please advise. Please see attached shop drawing for clarification. **Please also provide truss rail.**
 8. It appears that the two existing 6'+1H x 20'W aluminum single track cantilever slide gates have gate operators, do they work and is it in our scope to reconnect them once new gates are installed. **Existing gate openers are inoperable. No openers should be included in the bid.**
 9. The three existing 6'+1H x 6'W single swing pedestrian gates appear to be standard gates with gravity latches, not security gate. Do pad locks need to be provided or if required to be by others. **No.**
-

Ashley Robyck
Ashley Robyck, City Clerk

This Addendum must be acknowledged and included with the bid packet submission.

Signature

Company Name

Date
