

OFFICE OF THE SULLIVAN COUNTY PURCHASING AGENT  
3411 HIGHWAY 126 – SUITE 201  
BLOUNTVILLE, TN 37617-0569

*KRISTINIA DAVIS*  
PURCHASING AGENT

PHONE 423/323-6400

FAX 423/323-7249

[Kris.davis@sullivancountytn.gov](mailto:Kris.davis@sullivancountytn.gov)

# **ADDENDA-1**

## **REGARDING**

**RFP: WATER SOURCE HEAT PUMPS/ATTIC INSTALL /  
#1171800355(AM)**

**Re: CORRECTION OF EXISTING HEAT PUMP SIZING**

- 1. Based upon questions at the pre-bid on February 14, 2018, the tonnage information on page 3 of the RFP stating three (3) 2.5 ton heat pumps is incorrect.**

**Unit 6 is a 2-ton Vertical Water Source Heat Pump**

**Unit 12 is a 3-ton Vertical Water Source Heat Pump**

**Unit 14 is a 2.5-ton Horizontal Water Source Heat Pump**

**Each unit to be replaced with same tonnage water source unit as currently exists.**

PLEASE ACKNOWLEDGE RECEIPT OF THIS ADDENDUM TO THE EMAIL ADDRESS  
BELOW:

[alan.mahaffey@sullivancountytn.gov](mailto:alan.mahaffey@sullivancountytn.gov)