

## Responses to Inquiries #2

23-8-1

2023 Watermain Replacement and Resurfacing Project

1/26/2024

Inquiry submitted by	Inquiry	Response	Response From
Kelly Martini of Mauro Sewer Construction	For Item #12= CONTR LOW-STRENG MATL CY 500  Is this amount correct because it seems very high?	This pay item and quantity is to be used at the Engineer's discretion and as an option when consolidation of backfill is difficult or not possible or in instances where there is undermining of the pavement. e.g. where low cohesive soil is encountered in trench areas adjacent to patches and curb & gutter.	Kai T Liu Village Engineer Department of Community Development
Holly Lietzow of Performance Construction & Engineering LLC	We are wondering if the T-Head bolts need to be stainless steel? We do not see anywhere in the specs where it states they need to be stainless steel vs. steel.	Per Village specification, the bolts do not need to be stainless steel.	Kai T Liu Village Engineer Department of Community Development
Anthony Bucaro of Trine Construction Corp.	The sheets that are labeled "Return with Bid"- are those the only sheets required to be submitted with our bid (along with the acknowledged addendums and bid security)? Please advise if there is anything else required for submission.	In addition to the required IDOT forms, DuPage County forms including the conflict of interest, CDC conditions, and ownership forms are required to be completed and submitted. Proof of SAM.gov registration is also required. Check the bid packet for any others.	Kai T Liu Village Engineer Department of Community Development