



Florence County Government
Procurement Department

June 26, 2017

**ADDENDUM NO.3- JOHNSONVILLE BALLFIELD CANTEEN BUILDING RE-BID
(BID NO. 32-16/17)**

Florence County is sending to all interested contractors answers to questions concerning the bid document. The answers are highlighted in **BOLD RED** and underlined.

1. Question 1 of Addendum No. 1 states that a "1,000 lb live load, and an additional 1,000 lb dead load for storage are required in addition to the weight of the platform itself". Per Florence County a structural engineer would need to design the platform to meet such criteria and there is no structural engineer stamp on drawings or on bid documents. How should we proceed to price this with no structural engineer? **The Contractor will have to get a price from a structural engineer to verify the design per Florence County standards.**
2. Since there is a range shown in Canteen area, are we to assume that there will be food prepared in this area? **Food will not be PREPARED in this building. It will be heated in the microwave, but not prepared from scratch. The range is shown so that electrical power can be supplied, but it may be a freezer that occupies that spot.**

PLEASE ACKNOWLEDGE THIS ADDENDUM BY SIGNING BELOW AND SUBMIT IT WITH YOUR BID.

I have read and acknowledged page 1 of this addendum to bid no. 32-16/17.

Authorized Signature

Printed Name

Date

Company Name

County Complex

180 N. Irby Street MSC-R, Florence, SC 29501 Telephone (843) 665-3018 Fax: (843) 664-9668