



RE: Addendum #3 – Mary Wright Culture Wall

Please see the following question received and response given.

Question: See below from Lumicor about the change of temperatures being an issue, as for this being an exterior application they are concerned this Lumilight specified on drawings will not work. Attached is their second option for the back light of the Lumicor panels

“Unfortunately our team is unable to provide Lumilight for this project due to amount of temperature change that they will handle. We have another option call Light Sheet which my team is working on getting a quote for.

This will include a power enclosure that will control the lights. The electricians will have to install them.”

Response: Light sheet is an acceptable alternate for the Lumilight product originally specified. Light Sheet Product Overview and Installation Manual are included for ease of incorporating into bid. Please note in bids if Lumilight or Light Sheet is included in your pricing.