

## David Bernstein

---

**From:** David Bernstein  
**Sent:** Thursday, September 29, 2022 11:18 AM  
**To:** 'Stalvey Construction Co Inc'  
**Cc:** Jay Hood  
**Subject:** RE: [External]Questions for Whispering Pines Golf Course

Good morning.

In speaking with Jay Hood here are your answers.

The replacement windows are to be commercial storefront windows per the specifications on 23-B0014 and addendum 01 which would be anchored from head to foot.

There would be no need to paint them .Addendum 01 states the need for the anchoring, "pan system", and standard frame color of white as well as list of subcontractors before doing any of the work.

Please supply an itemized cost line with the bid for the removal and replacement of the cabinets and "other hanging things".

Thank you,

David Bernstein  
Buyer  
[dbernstein@cityofmyrtlebeach.com](mailto:dbernstein@cityofmyrtlebeach.com)  
843-918-2171

---

**From:** Stalvey Construction Co Inc <stalveyconcrete@yahoo.com>  
**Sent:** Thursday, September 29, 2022 9:56 AM  
**To:** Ann Sowers, CPPB, NIGP-CPP <ASowers@cityofmyrtlebeach.com>; David Bernstein <dbernstein@cityofmyrtlebeach.com>  
**Cc:** Stalvey Construction <stalveyconcrete@yahoo.com>  
**Subject:** [External]Questions for Whispering Pines Golf Course

**CAUTION: This email originated from outside your organization. Exercise caution when opening unsolicited attachments or clicking links. Please forward suspicious mail to [spam@cityofmyrtlebeach.com](mailto:spam@cityofmyrtlebeach.com) for review.**

-----  
Here are some questions we have for you:

Are the windows that have the rotten wood to be removed getting wood put back or the new window going to the ground?

The window frames are they painted or anodized?

On the inside of the building where the windows are there are cabinets and other things hanging. Are we to remove these things and put them back

when we are done or will Whispering Pines take care of this?

Thank You  
Kia Ford  
Project Manager/Estimator  
Stalvey Construction Co Inc  
1054 Savannah Bluff Rd  
Conway, SC 29526  
Office: 843-347-9453  
Cell: 843-591-6115