

**Metal Buildings  
For The  
City of Orange Beach  
Wastewater Treatment Facility**

**Addendum Number 1**

Plans and specifications shall be revised to reflect the following:

General:

Roll up doors shall be industrial grade, non-insulated.

Wall and roof panels shall be 26 gage or thicker.

Pipe Storage Building:

Overhang shall be 12" all around with no gutter or downspouts.

Workshop Building:

Overhang shall be 24" all around.

5 ton overhead crane shall be EMH Single Girder Crane Type ELV4 or approved equal suitable for Class B service.

Roll up door on south wall shall be 12' high. Roll up door on east (gable) end shall be 14' high.

Field Equipment Storage Building:

Overhang shall be 24" all around.

**NOTE: A SIGNED COPY OF THIS ADDENDUM MUST ACCOMPANY THE BID.**

BIDDER: \_\_\_\_\_

BY: \_\_\_\_\_

DATE: \_\_\_\_\_