

ADDENDUM THREE

TELEMETRY AND SCADA UPGRADES FOR MBWWTP AND VARIOUS LOCATIONS W-10-012-201 CITY OF CHATTANOOGA, TENNESSEE

The following changes shall be made to the Contract Documents, Specifications, and Drawings:

I. Clarifications

The following are questions received with associated answers.

1. Task 5: Supply and Installation of data paths at remote sites. Item 27 05 28.86 – Removal and replacement of pavement (Concrete & Asphalt). Does this item include the actual trenching and backfill?
 - a. **No this item is for the removal and replacement of pavement. All trenching and excavation is incidental to the cost of the conduit in which the cables are to be installed.**
2. **The City supplied Field Interface Unit (FIU) will not be delivered until January 2017. The Contractor will be required to install only RTU's that can communicate through the EPB internet until the FIU has been installed. After the FIU has been installed by the Contractor, the radio communications to these sites will need to be established.**



October 11, 2016

/s/ Justin C Holland, Administrator
City of Chattanooga,
Department of Public Works