



## ADDENDUM NO. 2

Issue Date: May 18, 2022

Project Name: Indian River Blvd Resurfacing from 53<sup>rd</sup> St to Barber Bridge (IRC-1707)

Bid Number: 2022046

Bid Opening Date: **May 26, 2022**

This addendum is being released to answer questions received to date. The information and documents contained in this addendum are hereby incorporated in the invitation to bid. **This addendum must be acknowledged where indicated on the bid form, or the bid may be declared non-responsive.**

### Questions and Answers

1. Regarding the inlet grates, can sizes of them be provided? If they are to be custom made to fit each structure we will need this information in order to accurately price this. **Grates out in the field are not within FDOT dimensional standards and will need to be custom fit and the County will need to review the shop drawings submitted by the Contractor. New grates are to be hot dipped galvanized reticuline steel and require H-20 loading. New reticuline grates should cover the full opening size. You should expect grates to be no larger than 10-SF in size of irregular dimensions. Contractor is encouraged to inspect grates and take measurements before submitting their bid.**