



SOLICITATION ADDENDUM

City of Leesburg | Purchasing Division
204 N. 5th Street | PO Box 4906030
Leesburg, FL 34749-6030
Phone: (352) 728-9880 | purch@leesburgflorida.gov

ADDENDUM NO. 1

Date Issued: June 13, 2018

Solicitation: 180431 – Airport Stormwater Improvements

The following changes are made to solicitation document 180431. Bidders shall take all information into account when preparing their bid response.

Language removed from the specifications is shown as ~~strike through~~. Language that is added or inserted show as ***bold, italic and underlined***.

REVISION TO SCOPE OF WORK

The following changes have been made to Section 2 – Scope of Work

SW-2. SCOPE OF WORK

- 2.1. Replace two (2) existing 20-inch concrete pipes, 356-feet from structure to structure with ~~two (2) new 20-inch reinforced concrete pipe (RCP)~~ ***one (1) new 30-inch reinforced concrete pipe (RCP)***. ***Contractor is responsible for modifying existing structures to accommodate new pipes.*** This pipe has a depth of 4-feet to 5.5-feet. Sixty-two (62) linear feet is in the tarmac area. Fifty (50) linear feet is in the taxiway and the remaining 244 linear feet is in the grass area.

All other elements of the Solicitation Document remain unchanged.

Please direct any questions related to this addendum to the Purchasing Office.

ACKNOWLEDGEMENT

It is the vendor's responsibility to ensure their receipt of all addenda, and to clearly acknowledge all addenda within their initial bid or proposal response in the space provided on the Certification/Addendum Acknowledgement Form included in the original solicitation document. Failure to do so may subject the bidder to disqualification.