

Bid #2203

Wastewater Treatment Plant Analysis

Amendment #1

This amendment hereby extends the due date to Monday, August 16th at 2:30 P.M.

This amendment hereby incorporates the attached list of tests into the Scope of Work.

BRICEVILLE Elementary School

<u>TYPE OF TEST TO BE RUN</u>	<u>FREQUENCY</u>	<u>RESULTS</u>
DISSOLVED OXYGEN (D.O.)	DAILY	AS OBSERVED 1.0 or Greater
CHLORINE RESIDUAL	DAILY	AS OBSERVED .5 or LESS
FLOW	DAILY	ASOBSERVED GAL. PER MINUTE
P.H.	2 TIMES A WEEK MON / WED	ASOBSERVED 6.0 – 9.0
SETTEABLE SOLIDS	2 TIMES A WEEK MON / WED	AS OBSERVED 1.0 or LESS
B.O.D.	1 TIME A MONTH	AS OBSERVED 30 or LESS
SUSPENDED SOLIDS	1 TIME A MONTH	AS OBSERVED 30 or LESS
E-COIL BACTERIA	1 TIME A MONTH	AS OBSERVER 126 or LESS

DUTCH VALLEY Elementary School

<u>TYPE OF TEST TO BE RUN</u>	<u>FREQUENCY</u>	<u>RESULTS</u>
DISSOLVED OXYGEN (D.O.)	DAILY	AS OBSERVED 3.0 or Greater
CHLORINE RESIDUAL	DAILY	AS OBSERVED .02 or LESS
FLOW	DAILY	AS OBSERVED GAL. PER MINUTE
P.H.	2 TIMES A WEEK MON / WED	AS OBSERVED 6.5 – 9.0
SETTEABLE SOLIDS	2 TIMES A WEEK MON / WED	AS OBSERVED 1.0 or LESS
B.O.D.	1 TIME A MONTH	AS OBSERVED 10.0 or LESS
SUSPENDED SOLIDS	1 TIME A MONTH	AS OBSERVED 30 or LESS
E-COIL BACTERIA	1 TIME A MONTH	AS OBSERVER 126 or LESS
AMMONIA NH3	1 TIME A MONTH	AS OBSERVED 5.0 or LESS