

BLEACHERS

INVITATION TO BID – REQUISITION NO. 2020-0305

ADDENDUM NO. ONE (1) – DATED FEBRUARY 28, 2020

The information given in this addendum is in addition to or supersedes conflicting information to the invitation to bid and is hereby made a part of the request.

Question #1: Under minimum specifications section there is a point that states the bleachers “must have closed deck”. Then further under section of Seats and Decking it states “Footboards shall consist of two 2"x10" nominal extruded (1.75"x9.5" actual) aluminum”. 2 footboards will give you semi-closed deck bleachers. Please advise which way to quote, closed deck or semi-closed?

Answer: The City requires a closed deck. Please disregard the conflicting information given under “Seats and Decking.”

Question #2: Since the bleachers are to be elevated, there should be stairs to access the front walkway. How many stairs would you need per bleacher?

Answer: The City has no requirement for number of stairs, as long as the stairs reach the minimum walkway plank height. The City requires that stairs be on both sides of the bleachers.

Question #3: Will the City install the bleachers? What type of surface will they be installed on? We recommend anchoring the bleachers to concrete slabs.

Answer: City crews will be installing bleachers on concrete slabs.

Please be sure to acknowledge receipt of this addendum on your bid form.