


## ELECTRICAL DEMOLITION PLAN

SCALE: 1" = 12'-0"

0' 6' 12' 24' N

## PLAN NOTES

1. EXISTING SITE LIGHTING FIXTURE AND POLE/BASE TO BE REMOVED. PROVIDE 12"X12" GRADE BOX AND DEMOLISHED POLE LOCATION AND PROVIDE NEW WIRING TO MAINTAIN SERVICE TO ALL DOWNSTREAM LIGHTING FIXTURES TO REMAIN. UNDERGROUND SPLICING FOR STREET LIGHTS IS NOT PERMITTED. SALVAGED POLES, LIGHT ENGINES AND GLOBES MUST BE DELIVERED TO CANTON CITY ENGINEERING, 2436 30TH ST NE, CANTON, OH 44705.
2. EXISTING SIGNAL LIGHT POLE TO REMAIN. MAINTAIN AND PROTECT DURING CONSTRUCTION.
3. EXISTING PEDESTAL WITH WEATHERPROOF CONVENIENCE RECEPTACLE TO BE REMOVED. REMOVE CONDUIT AND WIRING BACK TO SOURCE.
4. EXISTING 200 AMPERE, 120/240V IN-GRADE SERVICE VAULT TO REMAIN. MAINTAIN AND PROTECT DURING CONSTRUCTION.
5. EXISTING LIGHTING FIXTURE AND MASONRY BRICK BASE TO REMAIN. MAINTAIN AND PROTECT DURING CONSTRUCTION. SEE NEW WORK PLANS FOR NEW CONNECTION REQUIREMENTS.
6. EXISTING BRICK COLUMN WITH TOP MOUNTED LIGHTING FIXTURE TO BE REMOVED. REMOVE CONDUIT AND WIRING BACK TO SOURCE. SALVAGED SANDSTONE CAPS, LIGHT FIXTURES AND BRONZED STREET NAME SIGNS MUST BE DELIVERED TO CANTON CITY ENGINEERING, 2436 30TH ST NE, CANTON, OH 44705.
7. EXISTING PEDESTRIAN SIGNAL LIGHT TO BE RELOCATED TO NEW POLE LIGHT AT THIS LOCATION. REPLACE CABLE PER ODOT SPECIFICATIONS. CABLE SHALL BE CONTINUOUS FROM PEDESTRIAN HEAD TO SIGNAL CABINET, NO SPLICES PERMITTED. SEE DRAWING E2.01 FOR ADDITIONAL DETAILS.
8. EXISTING THIN HEAD INCANDESCENT LIGHTING POLE WITH PEDESTRIAN SIGNAL LIGHTS TO REMAIN. MAINTAIN AND PROTECT DURING CONSTRUCTION. SEE NEW WORK PLAN FOR LED RETROFIT REQUIREMENTS.
9. EXISTING LIGHTING CONTROL PANEL IN DEMOLISHED BRICK COLUMN TO BE REMOVED. PROVIDE NEW IN-GRADE PULLBOX TO INTERCEPT AND MAINTAIN EXISTING LIGHTING CIRCUIT TO THE NORTH ON COURT AVENUE. SEE DRAWING E2.01 FOR PULLBOX AND 2" CONDUIT EXTENSION DETAILS.


**MKSK**

LANDSCAPE ARCHITECTURE + URBAN PLANNING

462 SOUTH LUDLOW ALLEY
COLUMBUS, OHIO 43215
614 6212796 MKSKSTUDIOS.COM


client / owner
City of Canton

project name
CENTENNIAL PLAZA

project address
301-399 Market Ave N,
Canton, OH 44702


architect
SoL HARRIS/DAY
6677 FRANK AVENUE NW, NORTH CANTON, OHIO 44720
p 330.493.3722 | SOLHARRISDAY.COM

structural engineer
ARUP
77 WATER STREET
NEW YORK, NY 10005
p 212.896.3000 | ARUP.COM

civil engineer
ATWELL
7100 E PLEASANT VALLEY ROAD
SUITE 220
INDEPENDENCE, OH 44131
p 440.349.2000 | ATWELL-GROUP.COM

lighting design / electrical engineer
TEC STUDIO / TECH INC.
7510 SLATE RIDGE BOULEVARD
COLUMBUS, OH 43068
p 614.866.2868 | TECSTUDIOINC.COM

water feature
SOUTHERN AQUATICS, INC.
150 HILDEN RD
SUITE 305
PONTE VEDRA BEACH, FL 32081
p 904.824.1110 | SAIFOUNTAINS.COM


Not For Construction

| revision | date | issued |
|---|---|---|
| 1 | 06.21.2019 | ADDENDUM #2 |

seal

STATE OF OHIO
BRANDON M. SARGENT
PE.82305
REGISTERED
PROFESSIONAL ENGINEER
6/21/19

issue date

project number

sheet name
ELECTRICAL DEMOLITION PLAN

sheet number
E1.01