

ADDENDUM NO. 2

DATE: September 15, 2017
TO: All Bidders
FROM:  Boyce H. Evans, Purchasing Agent
SUBJECT: Addendum No. 2 – Cedar Lane Sidewalk Project
BIDS TO BE OPENED: September 20, 2017, at 11:00:00 a.m. Eastern Time

This addendum is being published to respond to a question that the City has received from a potential bidder. The City's response hereby becomes a part of the Contract Document and modifies the original specifications as noted below.

Question received:

- Question: What is the Typical for the Longitudinal Crosswalk?
- Response: The Longitudinal Crosswalks shall be continental style and 10 feet wide. The lines shall be 12" in width with a 12" gap and shall be parallel to the direction of travel by traffic.

END OF ADDENDUM NO. 2