



ITB #23-015  
Cemetery Road WWTP Ponds  
Expansion

Addendum #3  
Questions and Answers

---

**1) QUESTION:**

Is there a bid bond required?

**ANSWER:**

A payment bond and performance bond will be required of the awarded proposer for any contract that is greater than \$100,000. The performance and payment bonds will each be in an amount equal to 100% of the price specified in the contract. The bonds shall be executed by a surety company authorized to do business in the State of Florida, or otherwise secured in a manner satisfactory to the City for the protection of all persons supplying labor and material to the Contractor or its subcontractors for the performance of the work provided in the contract.

**2) QUESTION:**

Will burning of clearing debris be allowed onsite?

**ANSWER:**

No burning will be allowed.

**3) QUESTION:**

Will the removal of grass be required at stockpile areas? If so, can that be stockpiled as well?

**ANSWER:**

Only "clean dirt" will be stockpiled on City property. Soil containing grass or other debris must be hauled away.

**4) QUESTION:**

Will off-road trucks be allowed to cross a section of School Street to move fill to off-site stockpiles?

**ANSWER:**

Yes. However, any damage done to School Street must be repaired to County standards at the contractor's expense.

**5) QUESTION:**

What are the required elements of the as-built survey?

**ANSWER:**

A Licensed Professional Land Surveyor will issue 5 signed and sealed As-Built Survey's along with an Auto-Cad format As-Built drawing on CD showing all utility improvements to the Engineer of Record after completion of the project.

The as-built survey needs to include but is not limited to the following:

- Pond bank tops, pond slope bottoms.
- An approximate 100x100 grid of all areas that have been disturbed.
- Locates of all new inlets/valve boxes, pipe locations, inverts of all pipes in the valve boxes, the pond outfall pipes and their tops.
- Monitoring well locations and tops in NAVD 88 datum.
- Fencing and proposed gates.

---

#### ACKNOWLEDGEMENT

It is the vendor's responsibility to ensure their receipt of all addenda, and to clearly acknowledge all addenda within their initial bid or proposal response in the space provided on the Submittal Checklist included in the original solicitation document. Failure to do so may subject the bidder to disqualification.