



Georgetown County, South Carolina

129 Screven Street, Suite 239
Post Office Drawer 421270
Georgetown, SC 29442-4200
(843) 545-3083 • Fax (843) 545-3500
E-Mail • purch@gtcounty.org
Website • <http://www.gtcounty.org>

ADDENDUM #2 TO BID #21-040 REBID

BID NUMBER: 21-040 REBID

ISSUE DATE: Tuesday, November 9, 2021

OPENING DATE: Wednesday, November 17, 2021

OPENING TIME: 3:00 PM (ET)

Pre-Bid Site Inspection: Voluntary-On Own

PROCUREMENT FOR: Big Dam Swamp Recycle Center-General Contractor

This addendum will amend **Bid #21-040 REBID, Big Dam Swamp Recycle Center-General Contractor** originally issued on Wednesday, October 27, 2021. This clarification is being provided to all known and registered correspondents in response to questions received. All addenda and original bid documents are also available online at: www.gtcounty.org, select "Bid Opportunities" from the Quick Links section.

Question #1: Is there a specification on the grinder that will be installed?

Response: See Exhibit G, Note A at the bottom of the Unit Price Schedule which reads as follows:

NOTES	
A	INCLUDES CONTROL PANEL, ALARM AND REQUIRED ELECTRICAL. GRINDER PUMP SHALL BE MODEL NO. 9SF2V2D AS MANUFACTURED BY LITTLE GIANT, OR APPROVED EQUAL. 2" VENT/2" DISCHARGE. PEAK DAILY FLOW. THE DISCHARGE FORCEMAIN SHALL TIE INTO AN EXISTING SEPTIC TANK LOCATED BEHIND THE FIRE STATION. AVERAGE DAILY FLOW IS 100 GPD.