



City of Murfreesboro  
Purchasing Department  
111 West Vine Street  
Murfreesboro, TN 37130

*... creating a better quality of life*

**Addendum No. 2**  
**ITB-01-2018**  
**Mast Arm and Steel Strain Poles**

August 08, 2017

This Addendum No. 2 is issued in response to questions received. Addendum No. 2 modifies the original solicitation and is hereby incorporated and all other terms and conditions remain except the portions modified by addendum.

1. In regards to specifications: Poles shall be designed according to AASHTO Standard Specifications for structural supports for highway signs, luminaries, and traffic signals, 2001 edition.
2. Coat on mast arm is powder coated.
3. Finish on strain poles is galvanized.
4. In regards to section 4.1.3, "Pole finish – powder coated flat black paint", sentence should read "Pole finish – powder coated flat black finish."

Bidders are required to acknowledge receipt of **Addendum No. 2** in the space provided on the Signature Sheet in the original formal solicitation document.

**Failure to acknowledge all addenda may be cause for rejection of the response.**