



Florence County Government
Procurement Department

February 19, 2018

ADDENDUM NO. 1 - DIRT PAVING FOR DISTRICT 1 ROADS (BID NO. 25-17/18)

Florence County is sending to all interested companies answers to questions concerning the request for qualifications document. The answers are highlighted in **BOLD RED** and underlined.

1. Has a geotechnical investigation been performed with a report and mix design for the stabilized earth base? If not, will the contractor be required to hire a firm to perform this work? With that being said, is it safe to assume that the existing soils will be completely suitable for use in the stabilized earth base? **No geotechnical investigations have been performed for these projects. Contractor may hire a geotechnical firm at his option but it will not be required. Prior projects have had successful results with the on-site soils, however, contractor should review existing conditions and propose based on their experience with similar projects.**
2. The surface treatment / curing method is not specified, is it the intention to use the HMA Surface Course Type C in place of this? **Curing methods shall be chosen by the contractor and may be modified by the County engineer based on field results. Surface treatment may be applied at the contractor's option. HMA Surface Course is for final riding surface.**

PLEASE ACKNOWLEDGE THIS ADDENDUM BY SIGNING BELOW AND SUBMIT IT WITH YOUR QUALIFICATIONS.

I have read and acknowledged this addendum.

Authorized Signature

Printed Name

Date

Company Name

County Complex, 180 N. Irby Street MSC-R, Florence, SC 29501 Telephone (843) 665-3018

Fax: (843) 664-9668

Page 1 of 1