

# Tom Green County



113 W. Beauregard Ave.  
San Angelo, Texas 76903  
325-659-6500/Fax 325-659-5441

## RFP 20-003 Parks Grants: Construction Manager at Risk

6/15/2020

ADDENDUM NO 2:

Notice to Vendors:

Clarification:

1. Do you have any more details for the baseball and softball field structures and fencing as well as grass and material requirements for infield?

TGC Response:

Fencing – See attachment “Baseball-Softball Chain Link Fences and Gates”.

Grass/Turf – Tifway 419 Bermuda Hybrid\*

Infield Material – Diamond Pro infield mix or equivalent\*

Pitcher’s Mound, Home Plate, and Batters Boxes – Pitcher’s Mound Clay\*

Home Plate & Batters Boxes - Pitcher’s Mound Clay\*

\* Contractor is required to give submittals for approval prior to installation.

2. If onsite caliche is used, do we need to perform a proctor and at what quantities? **Both**

TGC Response: This will be performed by the County.

3. 5” wide by 4” tall concrete curbing for Granite Trail is shown but there was mention of that being replaced by metal edging. What is the detail for the approved change? **Pugh**

TGC Response: 5” tall 1/8 thick metal edging

4. What type of grass? Bermuda hybrid, sod, hydro mulch? What is the desired establish time for the playing field? **Pugh**

TGC Response: Tifway 419 Bermuda Hybrid.

5. Pump Station Details are missing **Pugh**

TGC Response:

Pump spec is RainBird or equivalent:

B1WPS package pump station

7.5 HP

3” inlet pipe from the river

Irrigation systems should be designed to use 70 gpm.

6. If Caliche is used at Harper Park, where is the source?  
TGC Response: The County will supply caliche.
7. There is no detail on the chain link fencing for the baseball field or the softball field. Measurements? **Pugh**  
TGC Response: See attachment "Baseball-Softball Chain Link Fences and Gates".
8. What bid item pertains to the Pugh Park Trail Improvements? **PUGH**  
TGC Response: Please refer to page 7, items 2-6. It refers to the oversight of Trails grant within the park perimeter.
9. Does the county have an all-inclusive list of donations we should be excluding from the quote? **BOTH**  
TGC Response: No list is available, please see "4. New Sample Bidding Template"
10. Does the county have a list of items of self-performance items that should be excluding from the quote?  
**BOTH**  
TGC Response: No list is available, please see "4. New Sample Bidding Template"
11. Does the county have a list of items donated labor (ie playground assembly, fitness assembly, scoreboards) that should be excluding from the quote? **BOTH**  
TGC Response: No list is available, please see "4. New Sample Bidding Template"

Please include this signed addendum with your response.

Sincerely,



Dustin Klein  
Procurement Supervisor

\_\_\_\_\_

Company

\_\_\_\_\_

Date

\_\_\_\_\_

Signature

\_\_\_\_\_

Please Print Name and Title