

Tom Green County



113 W. Beaugard Ave.
San Angelo, Texas 76903
325-659-6500/Fax 325-659-5441

RFP 20-003 Parks Grants: Construction Manager at Risk

6/18/2020

ADDENDUM NO 3:

Notice to Vendors:

- Please see attachment labeled “5. Press Box”
- **Drawings:** Architectural (TDLR Comments):
 - o Detail 2/A4.01 – Clarification – Sink to be 1’-8” from adjacent wall in lieu of 15”. Hand dryer shall not encroach on 30” wide ADA clear floor area for sink.
 - o Detail 6/A2.02 – Clarification – Controls for water closet to be on open side of water closet.
 - o Detail 1/A2.01 – Clarification – Benches to be ADA compliant, 20”-24” deep, fixed to wall.
 - o Sheet A2.04 – New press box, typical of (2) buildings. Building to be mirrored for softball field location.
 - o Sheet G-2 – Add – Add additional ADA parking space and striped aisle within the northernmost parking area (26 Spaces), to be concrete. Spaces for revision are to be the spaces with shortest path to facilities.
 - o Sheet G-2 – Add – Add additional ADA parking space within the “Gravel Parking Area (27 Spaces)” adjacent to currently proposed striped area, to be concrete.
 - o Sheet G-3 – Add – Add two additional ADA parking space and one striped aisle within the southwesternmost parking area (32 Spaces), to be concrete. Spaces for revision are to be the spaces with shortest path to facilities. Both spaces to be adjacent to striped area.
 - o Sheet G-3 – Add – Add three additional ADA parking spaces and two striped aisles within the southeasternmost parking area (112 Spaces), to be concrete. Spaces for revision are to be adjacent to currently proposed ADA Spaces. All spaces to be adjacent to at least one striped area.
 - o Sheets G-2 & G-3 – Clarification – Bleachers to be designed by others. Bleachers to meet all ADA requirements.
 - o Sheets G-2 & G-3 – Clarification – Dugouts to be designed by others. Dugouts to meet all ADA requirements.

- Sheets G-2 & G-3 – Clarification – Drinking Fountains to be designed by others. Drinking Fountains to meet all ADA requirements.
- Sheets G-1 – Clarification – Fitness Centers to be designed by others. Fitness Centers to meet all ADA requirements.
- Sheets G-1 – Clarification – Playground Area to be designed by others. Playground area to meet all ADA requirements.

Please include this signed addendum with your response.

Sincerely,



Dustin Klein
Procurement Supervisor

Company

Date

Signature

Please Print Name and Title