



Solicitation Number: 2023.013

Jayne Burritt, Administrator/CEO

Addendum Date: May 26, 2023

Board of Directors

Closing Date: June 12, 2023 @ 11:00 a.m. Eastern Time

Chuck Severance, Chair

Steve Maddox, Vice Chair

Total Pages: 1

Hubert Smith, Secretary

Shane Jackson, Treasurer

Revisions:

4.29 Site List: The elevator located at One Riverwalk Greenway is a Traction unit not Hydraulic.

Heather Anderson

Daniel Brown

Jon Clark

Scott Davis

Rob Glass

Jason Legg

Ann Marie Tugwell

Deletions/Additions:

Deletion #1:

4.19 ONLINE MAINTENANCE TRACKING PROGRAM:

Addition #1:

4.19 ONLINE MAINTENANCE TRACKING PROGRAM (IF APPLICABLE):

Addition #2:

4.17.12 Contractors are hereby notified that the elevator at the WFP Stair Tower uses vegetable grade oil. Proper procedures and clean-up must be followed in the event of a leak and/or spill.

Addition #3:

4.24.4 The awarded contractor(s) must maintain the two air conditioning units for the elevators located at the Sunsphere. These maintain air flow and temperature for the evaluator cabs and must function properly in the event of entrapment.

End of Addendum #2.

Addendum must be acknowledged in Tab III of the submittal.

Karen D. Smitherman, NIGP-CPP, CPPB, PMP
Manager of Procurement & Internal Controls
Public Building Authority