

	Lexington County School District Two	AMENDMENT #1 Date of Amendment: June 12, 2019	
		LEXINGTON COUNTY SCHOOL DISTRICT TWO PROCUREMENT SERVICES 715 NINTH STREET WEST COLUMBIA, SC 29169	Procurement Official Phone E-Mail Address

AMENDED SOLICITATION #	19-025-B
-------------------------------	-----------------

**INVITATION FOR BIDS
(IFB)**

DESCRIPTION	Audio & Video System for the Busbee Creative Arts Academy Cafeteria
-------------	--

NAME OF OFFEROR:	
AUTHORIZED SIGNATURE:	
TITLE	
PRINTED NAME:	DATE SIGNED

SEE AMENDMENTS TO SOLICITATION ON PAGE 2

AMENDMENTS TO SOLICITATION (JAN 2004): (a) The Solicitation may be amended at any time prior to opening. All actual and prospective Offerors should monitor the following web site for the issuance of Amendments: www.lex2.org (b) Offerors shall acknowledge receipt of any amendment to this solicitation (1) by signing and returning the amendment, (2) by identifying the amendment number and date in the space provided for this purpose on Page Two of the original solicitation, (3) by letter, or (4) by submitting a bid that indicates in some way that the bidder received the amendment. (c) If this solicitation is amended, then all terms and conditions which are not modified remain unchanged.

QUESTIONS FROM OFFERORS - AMENDMENT (JUN 2017)

The solicitation is amended as provided herein. Information or changes resulting from questions will be shown in a question-and-answer format. Questions received have been reprinted below. The “District’s response” should be read without reference to the questions. The questions are included solely to provide a cross-reference to the potential offeror that submitted the question. Questions do not form a part of the contract; the “District’s response” does. Any restatement of part or all of an existing provision of the solicitation in an answer does not modify the original provision.

THE FOLLOWING INFORMATION SHALL BE INCORPORATED AS PART OF THIS SOLICITATION:

QUESTIONS & ANSWERS:

Q. Are we able to make adjustments to the system design for improved reliability and performance?

A. No.

Q. Will the Behringer X32 be connected to the District network or a stand alone non-district network for control?

A. Stand alone.

Q. Where will the SD16 Expansion box be located? Assume to include 75' AES cable?

A. On stage and connects with a cat 5 cable.

Q. Where is the HDMI Switcher to be located?

A. On stage or in the booth.

Q. Who is responsible for the removal of existing speakers and lighting fixtures?

A. Contractor.

Q. Are vendors allowed to substitute equipment with other Manufacturers or is the bid brand specific?

A. Bid as specified. Alternates not accepted.

ALL OTHER TERMS & CONDITIONS REMAIN THE SAME!

END OF AMENDMENT #1