ADDENDUM NO. 2

TO THE DRAWINGS AND SPECIFICATIONS FOR THE New Rise STEM Academy for Girls Phase 1: Electrical Demolition Package Lexington, KY RTA 20045 BG# 23-547 FCPS Bid 10-24 01/11/2024

To All Plan Holders of Record:

This Addendum modifies the Invitation for Bid released on 1/03/2024 for the above project and shall become part of said documents in the preparation of proposals and execution of work of the subject project.

Drawings:

- 1. **Refer to Sheet E100:**
 - a) Revise according to **the attached sheet.**

END OF ADDENDUM



FLECTRIC GENERAL NOTES

- THE EXISTING TOPOGRAPHIC AND SITE INFORMATION SHOWN HAS BEEN PROVIDED BY AIM3D. THIS INFORMATION IS PROVIDED FOR THE CONVENIENCE OF THE CONTRACTOR. THE ARCHITECT SHALL NOT BE RESPONSIBLE FOR THE ACCURACY OF THE INFORMATION SHOWN THEREON. CONTRACTOR TO VERIFY ALL INFORMATION SHOWN; THE CONTRACTOR SHALL BE RESPONSIBLE FOR REPAIRING ANY DAMAGE TO UTILITIES SHOWN ON THE SURVEY.
- THE DRAWINGS SHOW THE APPROXIMATE LOCATION OF EXISTING AND PROPOSED UTILITY LINES. THESE LINES HAVE BEEN IDENTIFIED AND LOCATED AS ACCURATELY AS POSSIBLE USING AVAILABLE INFORMATION; THE CONTRACTOR IS RESPONSIBLE FOR VERIFYING ALL ACTUAL LOCATIONS.
- C. REFER TO SPECIFICATIONS FOR ADDITIONAL REQUIREMENTS.
- D. REFER TO ADDITIONAL SHEETS FOR INFORMATION AND REQUIREMENTS.
- E. FOR ALL AREAS WITH TREES 10' OR CLOSER TO PRIMARY LINE, CONTRACTOR SHALL SUPPLY AN OSHA LINE-CLEARANCE CERTIFIED CONTRACTOR TO ALLEVIATE ANY INCIDENTAL CONTACT WITH LINES.

ELECTRIC DEMOLITION KEYNOTES

- 1. LOCATION OF EXISTING TO REMAIN ELECTRICAL CONTROLS BOX FOR WATER PUMP. PROTECT PUMP AND ASSOCIATED CIRCUIT DURING TREE DEMOLITION AS REQUIRED. 2. LIGHTING CONTROLS BOX AT THIS LOCATION TO BE DEMOLISHED. DE-ENERGIZE ELECTRICAL CABLES SERVING LIGHTING
- CONTROLS CABINET. CONDUIT AND CABLES TO BE ABANDONED IN PLACE. 3. KU OWNED OVERHEAD PRIMARY LINE AT THIS LOCATION TO EXIST TO REMAIN. UTILITY POLES AND PRIMARY LINE TO BE PROTECTED FROM DAMAGE THROUGH THE ENTIRETY OF TREE DEMOLITION WORK IN THIS AREA. CONFIRM EXACT REQUIREMENTS WITH TYLER SKAGGS AT 859-367-4217 PRIOR TO TREE DEMOLITION AROUND ELECTRICAL UTILITIES IN THIS AREA
- $\sim\sim\sim\sim\sim$ 4. SITE LIGHTING, SECURITY AND A/V CIRCUITS ARE LOCATED ON APPROXIMATE QUANTITY OF 30 TREES NOTED TO BE DEMOLISHED ON PLANS. SAFE OFF AND DISCONNECT ALL SITE LIGHTING, SECURIN AND A/V CIRCUTS PRIOR TO REMOVAL WORK. REFER TO KEYNOTE 5 FOR SITE PANEL LOCATION. REMOVE CONDUIT AND CABLES SERVING MOUNTED ON AND AROUND DEMOLISHED TREES TO 6" ABOVE FINISHED GRADE. CONDUIT AND CABLES BELOW GRADE SERVING ALL DEVICES ON SITE TO BE ABANDONED IN PLACE FOR FUTURE DEMOLITION. TYPICAL FOR ALL ELECTRIFIED SITE DEVICES WITHIN DEMO SCOPE.
- 200A PANEL #1 SERVING SITE DEVICES LOCATED IN BASEMENT AT THIS LOCATION. SAFE OFF AND DISCONNECT ALL SITE LIGHTING, SECURITY, A/V, AND SITE CONVENIENCE RECEPTACLE CIRCUITS PRIOR TO TREE REMOVAL WORK. 6. LOCATION OF SITE RECEPTACLE. RECEPTACLE TO BE ABANDONED IN PLACE FOR FUTURE DEMOLITION. CIRCUIT SERVING SITE
- RECEPTACLE AND ALL OTHER SITE ELECTRICAL DEVICES TO BE DE ENERGIZED PRIOR TO WORK.
- . EC TO VERIFY ALL CIRCUITS SERVING SITE DEVICES PRIOR TO TREE DEMOLITION WORK. SAFE OFF AND DISCONNECT ALL CIRCUITS SERVING ANY SITE DEVICES SERVED FROM ANY PANEL. COORDINATE WITH TREE CLEARING CONTRACTOR ON SITE PRIOR TO WORK.

LECTRIC LEGEND

CONTRACTOR



 $\boxtimes \boxtimes$

EXISTING TREE(S) TO BE REMOVED BY TREE REMOVAL CONTRACTOR.

EXISTING TREE(S) TO BE REMOVED BY TREE REMOVAL





366 south broadway lexington, ky 40508 p. 859.389.6533 f. 859.389.6534 www.element-site.com



