

## ADDENDUM NO. 2

<b>DATE OF ISSUANCE:</b>	<b>August 09, 2021</b>
<b>PROJECT:</b>	<b>Video Surveillance Upgrades - 2021</b>
<b>OWNER:</b>	<b>Portage Public Schools</b>
<b>ARCHITECT'S PROJECT NO.:</b>	<b>21-150</b>
<b>ORIGINAL BID ISSUE DATE:</b>	<b>July 28, 2021</b>

---

### SCOPE OF WORK

This Addendum includes changes to, or clarifications of, the original Bidding Documents and any previously issued addenda, and shall be included in the Bid. All of these Addendum items form a part of the Contract Documents. The Bidder shall acknowledge receipt of this Addendum in the appropriate space provided on the Bid Form. Failure to do so may result in disqualification of the Bid.

### DOCUMENTS INCLUDED IN THIS ADDENDUM

This Addendum includes **three (3)** pages of text and the following documents:

- Bidding Documents: **none**
- Contract Conditions: **none**
- Specification Sections: **00 4100 – BID FORMS**
- Drawings: **none**

### CHANGES TO PREVIOUSLY ISSUED ADDENDA

Bidders are to disregard the Addendum 1 answer/instructions for **Addendum 1 Item ADD-1 Item No. A-5 – Question regarding mounting accessories for 360 multi-sensor cameras**. Below is the original question, and the revised official answer to the question:

Question: I am requesting confirmation that there aren't any mounting accessories required for the 360 multi-sensor cameras. Normally I might add:

H4AMH-AD-CEIL1 ceiling mount and/or H4AMH-DC-COVR1 bubble & cover in ceiling

It appears that some of the 360 are hard-deck and some are drop tile ceiling mounts. Thank you for the clarification.

Answer (Addendum 2 revised): *Bidders shall disregard the answer for Addendum 1 Item: ADD-1 Item No. A-5. Bidders are instructed as follows:*

*For all ceiling-mounted multi-sensor cameras (any type of ceiling and any multi-sensor 180, 270 and 360 cameras), provide the following components in addition to the camera module as specified per location:*

*H4AMH-AD-DOME1 and H4AMH-DO-COVR1*

*The intent is that the surface-mounted H4 multi-sensor dome is provided at each ceiling-mounted location regardless of the type of ceiling that it mounts to (rather than using the in-ceiling recessed multi-sensor mount at certain locations). Note: all other mounting types defined by the camera schedules (e.g. surface pendant, corner mount pendant, etc) shall be the part numbers as specified in the camera schedules.*

**ANSWERS TO SUBMITTED QUESTIONS**

**ADD-2 Item No. A-1 - Question regarding cameras CHS-E19, CHS-E20, and CHS-E21**

Question: are camera CHS-E19, E20 and E21 at Portage Central going to be camera replacements? I don't see a technology note next to these three.

Answer: *CHS-E19 and CHS-E-20 are camera replacements. Camera CHS-E21 is a new location.*

**ADD-2 Item No. A-2 – Question regarding lift fees**

Question: Are we to include lift fees in our base bid?

Answer: *No. A revised bid form is included as part of this Addendum. A line has been added for the bidder to enter a daily lift fee, to be used for a contract addition if a lift is needed. Bidders are instructed to include necessary floor and/or ground protection in this daily fee. The camera contractor shall be liable for any property damage caused by a lift.*

**CLARIFICATIONS**

**ADD-2 Item No. C-1 – Scope clarification**

The scope of this project does not include the provision of any data cabling or rough-in/pathway for any new camera locations. However, the camera contractor shall be responsible for coordination with the owner's data cable contractor and the owner.

**PRE-BID MEETING ATTENDEES**

**ADD-2 Item No. M-1 – PRE-BID MEETING ATTENDEE LIST AND CONTACT INFORMATION**

A Non-mandatory pre-bid meeting was held on August 5, 2021 at Portage Public Schools Administration. A list of contractor attendees, listed in the order of sign-in, is below.

<b><u>Name</u></b>	<b><u>Company</u></b>	<b><u>Email</u></b>	<b><u>Phone</u></b>
Tim Kern	Classic Office Systems	<a href="mailto:timk@classicofficesystems.com">timk@classicofficesystems.com</a>	616-819-9555
Steve Deerman	Security 101	<a href="mailto:sdeerman@security101.com">sdeerman@security101.com</a>	480-678-3064
Luke LeaTrea	Presidio	<a href="mailto:lleaTrea@presidio.com">lleaTrea@presidio.com</a>	616-295-6138

**END OF ADDENDUM.**