

**SUPPLEMENTAL INFORMATION**  
**ADDENDUM NO. 2**

PROJECT: RFQ No. 20-29-004 – Sandhill Recreation Complex - Upgrades

CONTACT: Fiona Charleton, Purchasing Agent  
912-754-2159 [fcharleton@effinghamcounty.org](mailto:fcharleton@effinghamcounty.org)

DATE ISSUED: January 15, 2020

---

RFQ No. 20-29-004 dated November, 2019 is hereby amended as noted herein : BIDDER TO ACKNOWLEDGE RECEIPT OF ADDENDUM BY SIGNING ON THE SIGNATURE LINE BELOW AND INCLUDING A COPY WITH SUBMITTED BID. FAILURE TO DO SO MAY, AT THE OWNER'S DISCRETION, SUBJECT THE BIDDER TO DISQUALIFICATION

**Attached is the topography map of the area that was requested at the mandatory pre-bid site visit.**

- 1) QUESTION: Product for the Basketball Court and product coverage? Are we covering the entire court or just painting the lines?

**ANSWER: See also Section 2 of the scope-**

**Basketball court – Outdoor – finishes with lines**

- 1. Court needs to cure for at least 30 days**
- 2. Etch concrete with muriatic acid**
- 3. Then surface binder**
- 4. 2 coat of color coating**
- 5. Paint lines (EXACT SIZE TO BE DETERMINED PRIOR TO SECTION 2 WORK)**

- 2) QUESTION: We asked about the turf yesterday but wanted to clarify to bid the Standard Tunnel Roll turf and give an alternate on the Diamond Turf? That is the way I took it yesterday and is the way Greg Oliff, the preferred turf supplier/vendor assumed it.

**ANSWER: Yes, both need to be put on bid to avoid delaying the process- Greg Oliff is the person I gave at our first meeting from BSN Sports.**

- 3) QUESTION: Is there a particular disc golf manufacturer the County wants to use?

**ANSWER: Does not matter, Innova Disc Golf is where most of the specs came from.**

- 4) QUESTION: Greg said he had spoken with one of the staff about not being able to put the batting cages butted up to one another side by side. Two options of either


have space between the two cages or the slab would have to be bigger than the specified 30'-0", possibly 35'-0"

ANSWER: Batting cages will be side by side with a possible 4'-8' distance between them. This space will not be concrete.

**INTENTIONALLY LEFT BLANK**

School →

Bench Mark 0



Entrance

All other terms and conditions in RFQ No. 20-29-004 remain unchanged.

Effingham County reserves the right to reject any and all proposals, to waive any technicalities or irregularities and to award the offer based upon the most responsive, responsible submission.

Please sign receipt of this Addendum No. 2 below:

\_\_\_\_\_  
Print Name

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Date

**END OF ADDENDUM NO. 2**

**INTENTIONALLY LEFT BLANK**