

“City of Havelock

Rebuilding Culvert Bridge at Sermon’s Park”

Addendum 1

June 2, 2021

Revised Drawing for Figure 2 attached

Questions Received

1. Since the 54” concrete pipes are made in 8 foot sections, is it ok to use three sections and make the overall length 24 ft. instead of 20 ft.?

Yes. The overall length can be 24 ft. Refer to Scope Section “Material” and note that THREE sections of 8’ x 54” concrete pipe to be used instead of one. Figure 2, drawing 3 dimension to be 24 ft., not 20’.

2. Because of the steep grade of the sides of the ditch, can the wingwalls be straight and level with the headwalls, including railing?

Yes. Scope Figure 2 drawings: disregard sloped wingwalls and rails; Keep tops of wingwalls and rails even with top of headwalls.

3. Does the City want to replace the existing asphalt with new paving?

No. since the existing asphalt is in such disrepair and overgrown, and that there is no other paving in proximity, please follow the scope Sections “Backfill and Compaction” and “Erosion and Sediment Control and Surface Restoration and Figure 2 drawing 3 to provide gravel, fill and sod.

4. Are there any utilities in the work area?


We have no record that utilities run through this area but it is the Contractor’s responsibility to notify 811 and request a utility locate. Refer to Scope section “Excavation and Shoring” and “General Provisions-G”.

5. Can I get a copy of the prebid sign in sheet?

Attached.

FIGURE 2. ELEVATION, PLAN, SECTION

SCALE $\frac{3}{16}''=1'$



Sermons Park site visit sign in sheet

Name	Title	Organization	Telephone	Email
Patrick Lee	Public Works Director/ Interim Utilities Director	City of Havelock	252-675-2942	plee@havelocknc.us
Rick Day	City Engineer	City of Havelock	919-353-3675	rday@havelocknc.us
Donald Dean	Streets Supervisor	City of Havelock	252-444-6409	ddean@havelocknc.us
Bishop Williams	VP of Operations	Waters Contracting	919-279-7265	bishop@waterscontracting.com
TC Cleave	PROJECT MANAGER + Const. Layout	Sunland Builders	252-725-3603	tc_cleave@yahoo.com
Jimmy John	President	Carter Marine	252-631-9435	Jimmy@cartermarine.com