

ADDENDUM NUMBER FOUR

MOCCASIN BEND O&C BUILDING RE-ROOFING PROJECT CONTRACT NO. W-16-015-201

CITY OF CHATTANOOGA, TENNESSEE

The questions and comments below were received. Answers and responses are listed in bold-faced letters.

1. Please clarify wind speeds – Spec. Section 075423-1-D calling for FM Class A-90.

These are essentially the same specs that were used on the Filter Press Building project. FM Class A-90 is not a wind speed spec; it is a wind uplift pressure spec in terms of pounds per square feet. The other reference to wind speeds in the spec is an exclusion to damages created by peak wind gust speeds exceeding 120 mph.

2. There are two (2) TPO Specs – Which do we use.

Use 075423, TPO Fully Adhered.

3. DensDeck or Equivalent is listed on bid form – which TPO spec – one calls for it, one does not. If DD is required someone needs to provide thickness.

Use 5/8” cover board. It can be Dens-Deck or equivalent, as noted on the bid form.

4. Can someone please go through the spec and clean up. Filter Press and Boiler Buildings are all through the spec and not O & C.

Done.

September 15, 2016

/s/Justin C Holland, Administrator
City of Chattanooga
Department of Public Works