## **Bear Island Road Paving Project**

## Addendum No. 5

April 25, 2019

This Addendum forms a part of the Contract Documents and modifies the original documents as herein described. Bidders shall acknowledge receipt for the addendum on the Bid Form.

Question 1: Based on the language in addendum #3, HP Polypropylene is only one option that may be considered for pipe not under roadway and within SCDOT ROW. However nowhere does it state that regular HDPE is not allowed everywhere else. Is the intent of Town of Summerville to allow regular HDPE on the project? Please clarify.

Response: The contractor may use any SCDOT approved smooth wall pipe that meets SCDOT standard drawings and specifications. The Town will also allow the use of HP STORM Polypropylene Pipe as longs as it meets the SCDOT standard drawings and specifications. Concrete pipe shall be used under the roadway and within SCDOT's right-of-way in all cases.

End of Addendum No. 5