



St. Johns River Water Management District

Michael A. Register, P.E., Executive Director

525 Community College Parkway S.E. • Palm Bay, FL 32909 • 321-984-4940 • www.sjrwmd.com

DATE: November 2, 2023
TO: Prospective Respondents
FROM: Amy Lucey, Procurement Specialist
SUBJECT: Addendum #1 to Invitation for Bid, # 39302, Geosynthetic Slope Stabilization Welland Road – Lake Apopka

As a result of inquiries, the following clarifications/changes are provided for your information. Please make all appropriate changes to your bid documents.

- Q1: Page 44 in the bid documents shows horizontal measurements but does not provide vertical elevations. Can the department provide us with the anticipated elevations (top and toe of material placement) for this bidding project?
- A1: The vertical depth is approximately 3-foot (from top of geosynthetic to toe of slope or bottom)
- Q2: Is the cause of the destabilization the result of shoreline erosion? This information will assist me in evaluating the potential for our system to mitigate the problem and to determine if we should pursue a bid.
- A2: For the most part, the answer is yes. The slope on the AB Canal has substantial wave action from boats that has caused most of the erosion. The slope along Welland also sees significant wave action that has contributed to the erosion but in addition high water levels from past storm events saturated the slopes and when the water levels receded the slopes began to slough as a result.

NOTE: The Bid Due Date remains **2:00 p.m. Friday, December 1, 2023**

Please acknowledge receipt of this Addendum on the Bid Form provided in the proposal package.

If you have any questions, please e-mail me at alucey@sjrwmd.com.