



## Jackson County Board of Commissioners

67 Athens Street  
Jefferson, Georgia 30549  
Phone: (706) 367-6309  
Fax: (706) 708-2505  
Email: myarbrough@jacksoncountygov.com

Date: September 21, 2022

To: General Contractors

From: Myrna Yarbrough, Purchasing Manager

**RE: Addendum 2 to Jackson County ITB 220028, Renovations and Site Work for the Elections Department at the Gordon Street Center, Jackson County GA.**

1. Answers to questions are attached. All other information remains the same.
2. All other terms and conditions in ITB 220028 remain unchanged.
3. Any inquiries concerning Addendum 2 should be made to Myrna Yarbrough, Purchasing Manager, (706) 367-6309 or via email at [myarbrough@jacksoncountygov.com](mailto:myarbrough@jacksoncountygov.com)
4. Jackson County reserves the right to reject any and all proposals, to waive any technicalities or irregularities and to award the offer based upon the most responsive, responsible submission.
5. Bidders must acknowledge receipt of addenda, by either signing and attaching this copy, or by writing "Acknowledge Addenda #2" at bottom of the proposal.

- 1) Are these two automatic doors going to be singles or pairs? Automatic from the outside only or both outside and inside?
- 2) Are they going to be a standard color, a clear anodized finish or a dark bronze anodized finish?
- 3) With the existing panic hardware, are these going to be dog down during the day so the ADA operator can swing freely or do these need to be retrofitted so they will automatically retract when the automatic door swings open?

New 6'x7' pair of Kawneer 500 wide style doors with 10" bottom rail

Von Duprin concealed rod panic with dogging device both leaves

1 1/2 offset pivots per leaf

Bottom door sweeps

Besam top of the line ADA operator on the right leaf. With push pad operation inside and outside.

LCN 4040 closer on left leaf

1/4" clear temp glass

15" 1" dia. bent bar pull on both leaves exterior

Over head concealed door stop on left leaf

- 1) What size are the tubes for the railing? - (1 1/2" Diameter) see detail 5 on sheet C-102
- 2) What is the total length of the railing? - See detail 5 on sheet C-102 (field verify length)