



Front St Underground (UG) Infrastructure Upgrade T3
Project No. 1927 Material Rebid
ADDENDUM I
Answers to Questions

1. For the 500 and 350 AL 600 V secondary cables, can you use black with the ends taped or do they need true colors?
For the purposes of the material bid, the City was hoping to determine whether the true colored cables were available and at a reasonable price. However, it is not required to quote the colored cable. If possible, please provide quote on each colored cable to allow the City to determine whether to use colored cables or all black cable.
2. On lines 43-45, do we need to quote XLP or SuperTuf?
Please quote XLP.
3. What Neutral is needed for line 37?
Provide full neutral for the medium voltage cable.

The date and time of the submissions have not been changed. Bids are due on or before 2:00 PM EST, Tuesday, September 5, 2023.