



City of Alamogordo

Purchasing Office 2600 N. Florida Alamogordo NM 88310 Phone (575)439-4116

March 1, 2022

To: All Bidders

Re: Addendum No. 1

RFP No. 2022-004 Water Storage Tank Inspection and Cleaning Services

Each bidder shall acknowledge receipt of this Addendum Number One (1) by including in Proposal packet. This addendum will not be counted as part of the maximum page limit.

Addendum Number 1 is issued to provide changes and/or clarifications to the above referenced RFP as per the following:

- 1. Question:** Can you verify that all of the tanks have a 24" or larger water access hatch?

Answer: All tanks are equipped with a 24" manway

- 2. Question:** Can you provide the addresses (or coordinates) for the tanks so we can view them on Google Maps?

Answer:

Site Name - Description	Longitude	Latitude	Heading	Coordinates
Callahan Ground Storage Reservoir	-105.9252327	32.91774005	2.782478897	-105.9280590071577,32.9189272911991,0
Foot Hills Ground Storage reservoir	-105.9198501	32.89022032	2.78540419	-105.9190513551214,32.89105889866453,0
Green Ground Storage reservoir - 5MG	-105.9393095	32.95141428	6.922609975	-105.9392793383719,32.9513249234921,0
Lower Alamo Ground Storage Reservoir	-105.9276655	32.87515503	2.781161105	-105.9292793244647,32.87466102791034,0
Lower Heights Ground Storage reservoir	-105.9182761	32.90616738	2.786258861	-105.9180419421226,32.90412490664485,0
Ocotillo Ground Storage Reservoir	-105.9413344	32.87648668	2.839490406	-105.9420633014405,32.87501193562291,0
Westside Elevated Storage Reservoir	-105.9693389	32.93999265	2.764842814	-105.9709478739962,32.94011670241599,0
Westside Ground Storage Reservoir	-105.9693389	32.93999265	2.764842814	-105.9714719714958,32.94008387070399,0

3. **Question:** Do any of the tanks have baffles? (If yes, may we get drawing of the tanks?)

Answer: None of the tanks are equipped with baffles

4. **Question:** Can you provide as-builts of tanks so we can see column orientation (which might affect cleaning time/dive equipment)

Answer: The city does not have as-built data on the tanks

5. **Question:** Does each site have truck/trailer access?

Answer: All tank sites are accessible with a truck and trailer with plenty of room for maneuverability.

6. **Question:** When was the last cleaning/inspection of listed storage tanks?

Answer: Last cleaning/inspection was in 2015

7. **Question:** Will the City provide an address or GPS locations for each storage tank?

Answer: Yes. Please see the answer to question 2.

8. **Question:** Is professional Liability Insurance a requirement for this scope of work?

Answer: No

All other provisions of the Contract Documents shall remain unchanged. This addendum is hereby made part of the Contract Documents. Each bidder shall acknowledge receipt of this Addendum Number One (1) using the attached acknowledgement page and submit with each copy of the proposal (not included in page count).

Thank You,

Barbara Pyeatt
Chief Procurement Officer
bpyeatt@ci.alamogordo.nm.us

ADDENDUM ACKNOWLEDGEMENT

ADDENDUM NO. 1

RFP No. 2022-004 Water Storage Tank Inspection and Cleaning Services

Received By: _____

Date Received: _____

Business Name: _____

Name: _____

Signature: _____

