

**OFFICE OF THE SULLIVAN COUNTY PURCHASING AGENT**  
**3411 HIGHWAY 126 – SUITE 201**  
**BLOUNTVILLE, TN 37617-0569**

**KRISTINIA DAVIS, CPPB**  
**PURCHASING AGENT**

PHONE 423/323-6400

FAX 423/323-7249

[Kris.davis@sullivancountytn.gov](mailto:Kris.davis@sullivancountytn.gov)

**ADDENDUM NO. 3**

Date Issued: March 26, 2021

Bid No.: #1412131(KD)

Bid Title: Sullivan East Middle School Site Lighting

Re: East Middle School

This addendum is issued to answer a question received as of 3/26/21 for this work and shall be considered as part of the contract subject to all the general conditions thereof, the same as if attached to and included in the original specifications. All items included in the addendum shall be covered in the Bid as submitted by the Contractor.

1. Can rigid conduit be used instead of running through the concrete pedestal to keep from disturbing it?

**Answer:** Yes, if it meets code and passes inspection.

End of Addendum No. 3