



Terry McKee, IT & Procurement Director

901 Broadway N. ♦ Knoxville, TN 37917-6699
 865.403.1133 ♦ Fax 865.594.8858
 purchasinginfo@kcdc.org
 www.kcdc.org

Addendum

| SOLICITATION NAME | Renovation Services at Mechanicsville I C17009 Renovation Services at Mechanicsville II C17010 Renovation Services at Valley Oaks C17008 | ADDENDUM NUMBER | A | DATE | 10-12-16 |
|-------------------|--|-----------------|---|------|----------|
|-------------------|--|-----------------|---|------|----------|

This addendum answers questions raised about this solicitation. To aid in readability, the questions are in black, the answers are in **bolded blue**, and the answers follow immediately below.

| | |
|----|--|
| Q1 | Is the use of wire mold approved? |
| | Yes. |
| Q2 | Is there an existing hot water heater disconnect circuit? |
| | Mechanicsville I & II: Water heaters are gas. Valley Oaks: No disconnects just a breaker for the water heater in the panel box. |
| Q3 | Is there an existing circuit for dishwashers? |
| | Mechanicsville I & II: No disconnects. Valley Oaks: No disconnects just a breaker for the dishwasher in the panel box. |

