

September 12, 2023

ADDENDUM TO ADVERTISED CONTRACT

Project Name: City of Holly Springs Depot Renovation Project

Project Number: RFB # 2023-03

City: City of Holly Springs

Addendum Number: 2

Bid Date: September 20, 2023

The following changes are hereby made to this request for bids. The bidder is responsible for making any necessary changes in ink in the bid. Bidders shall acknowledge this addendum by checking the appropriate space on the addendum certification document.

Questions/Clarifications

1. All references in the plans of the 5/4x6 decking board specification shall be with 2x6 #2 Prime Decking Pressure Treated - Micronized Copper Azole (MCA). After installation all surfaces shall be treated with "Seal-Once" Marine Premium Wood Sealer or approved equal applied as per manufacturer specifications.
2. All fasteners shall be galvanized screws and sized per industry standards.