ADDENDUM NO. 2

DATE: June 8, 2017

TO: All Bidders

FROM: Boyce H. Evans, Purchasing Agent, City of Knoxville

SUBJECT: Addendum No. 2 – Facilities Paving at 913 E. Fifth Avenue

Project

PROJECT NO.: 17W-P-0636

BIDS TO BE OPENED: June 14, 2017, at 11:00 a.m. (Eastern Time)

This addendum is being published to respond to questions asked by potential bidders regarding the Facilities Paving at 913 E. Fifth Avenue Invitation to Bid. This addendum becomes a part of the Contract Document and modifies the original specifications as noted.

Changes to the Contract Documents & Specifications:

Bid Proposal

A revised bid proposal form is attached to this addendum. The following is a summary of the changes made:

- 1.) Item No. 1.10, Mobilization of Forces, Supplies and Equipment (Max Amount = \$4,000 + 3% of Contract Amount) has been added.
- 2.) Item No. 2.20, Pavement Preparation has been added.
- 3.) Item No. 9.30, Bituminous Plant Mix, Grading C has been added.

Clarification of Contract Documents & Specifications:

Question #1: Will the contractor be responsible for cleaning out the pipe connected to the area drain that will be replaced? If so, how will this be paid?

<u>Response</u>: Yes, the contractor will be responsible for cleaning out the pipe and the cost for this work shall be included in the cost of Item No. 22.15, Area Drain.

Question #2: Would the City consider adding a 1LS Mobilization Item, to cover the cost of all the mobilization and all the cost to clean the existing asphalt surface in preparation for resurfacing? Response: Yes, the City will add lump sum Item No. 1.10 Mobilization of Forces, Supplies and Equipment (Max Amount = \$4,000 + 3% of Contract Amount) which shall include mobilization for both sites. Item No. 2.20, Pavement Preparation has been added to cover the cost of cleaning the asphalt surface as detailed in the pavement preparation section of the Special Conditions.

Question #3: Would the City consider adding a leveling course of 307-01.15 ACS Mix (PG64-22) (BPMLC-HM) Grading CS?

<u>Response</u>: The City has added Item No. 9.30, Bituminous Plant Mix, Grading C to be used for leveling as directed by the engineer.

END OF ADDENDUM NO. 2

BID PROPOSAL CITY OF KNOXVILLE, TENNESSEE

Facilities Paving at 913 E. Fifth Avenue Project Project No. 17W-P-0636

TO THE PURCHASING AGEN	ľ
CITY OF KNOXVILLE, TENNI	ESSEE

hereby propose(s) to furnish all material, labor, and appliances and do all work required to complete the Contract for the Facilities Paving at 913 E. Fifth Avenue Project, Project No. 17W-P-0636, located in the City of Knoxville, Tennessee, in a workmanlike manner and in accordance with the plans of the Department of Engineering and specifications herewith attached.

Bidder further agrees that in case of failure to sign a delivered contract within thirty (30) days, the certified check or bid bond accompanying this bid and the proceeds thereof shall be the property of the City of Knoxville if the City chooses to retain said bid bond or check.

BID SCHEDULE

ITEM NO.	DESCRIPTION	UNITS	TOTAL QUANTITY	PRICE PER UNIT	TOTAL PRICE PER ITEM
1.10	Mobilization of Forces, Supplies and Equipment (Max Amount = \$4,000 + 3% of Contract Amount)	LS	1		
2.20	Pavement Preparation	LS	1	_	
5.10	Mineral Aggregate Base	TON	525		
7.10	Tack Coat	GAL	900		
9.20	Bituminous Plant Mix, Grading B-M	TON	225		
9.30	Bituminous Plant Mix, Grading C	TON	40		
10.20	Asphaltic Concrete Surface, Grading E	TON	780		
10.40	Pavement Removal (up to 2 ft. in depth)	SY	1,150		
22.15	Area Drain	EA	1		
22.42	Adjustment of Existing Area Drain	EA	21	_	
38.10	Milling or Grinding of Asphalt (Surface Milling)	TON	175		
39.10	Pavement Marking (4" Line)	LF	2,700		
39.70	Pavement Marking	LI	2,700		
58.20	(Channelization Striping)	SY	100		
38.20	Adjusting Manhole Frames (Adjustment Ring Only)	EA	8		

ITEM			TOTAL	PRICE	TOTAL PRICE
NO.	DESCRIPTION	UNITS	QUANTITY	PER UNIT	PER ITEM
58.30 58.40 70.10 70.20	Adjusting Utility Valves Adjusting Water Meters Wheel Stops Wheel Stops (Adjustment Only)	EA EA EA	9 2 17 6		
TOTAL BID (In Words):		TOTAL B	ID	\$	