

Bid #4781 Construction of Steel Building

Questions and Answers

July 26, 2017

1. Is there a specification for doors, siding material, insulation, gutter, etc... ?

Answer: The specifics may vary according to the vendor that will be providing the materials. In general, the doors will be (2) standard size walk-thru steel doors with steel frames, the 10' x 10' roll-up door and the 12' x 18' roll-up door will be made of the same steel as the siding. The gauge of steel needs to be industry standard. The insulation is rolled R10-R13 plastic backed insulation for the walls and roof, guttering and downs will most likely be aluminum riveted gutters. The building will have steel beam and purling supports and will be a clear-span building (open in the middle, no down beams in the middle of building).