



ADDENDUM # 2 SOLICITATION IFB 2019-47

Restroom Facility at 68 Boundary Street (re-bid)

This addendum is being issued to announce, revise, clarify and address questions or certain issues that have occurred since the solicitation was originally issued.

All contents of this addendum shall be incorporated into the solicitation documents and the ensuing contract with the awarded Contractor. It is the Contractor's responsibility to ensure their receipt of all addenda, and to clearly acknowledge all addenda in the place indicated on the Bid Proposal page of the IFB. Failure of a Contractor to acknowledge each addendum may prevent the bid from being considered for award and deem the Contractor as non-responsive.

Addendum, revised forms and documents attached hereto shall not be altered and attached to bid submittals in their original format.

CHANGES TO TECHNICAL SPECIFICATIONS, PLANS, DRAWINGS

The exhaust fan specified in the IFB is apparently no longer available. Please substitute the following Grainger fan: Dayton 12" X 12" 115VACV medium duty direct drive exhaust fan with 8" blade diameter. It is manufacturer's model number 10D952.

The job requires two units (one for each restroom) rated at 300 CFM.

All prospective Respondents are reminded and hereby instructed not to contact any member of the Town of Bluffton Council, Town Manager or Town of Bluffton staff members, other than the noted contact person OR the Town's Purchasing Administrator regarding this IFB or their response at any time during the solicitation and award process. Any such contact shall be cause for rejection of your submittal.

ALL OTHER SPECIFICATIONS, TERMS AND CONDITIONS REMAIN UNCHANGED