 <p>CLAYTON COUNTY Water AUTHORITY</p> <p>1600 Battle Creek Road, Morrow, GA 30260</p>	Jesters Creek East Outfall Replacement - Phase 1	
	ADDENDUM 1	
	DATE	March 26, 2019
	BID NUMBER	2019-PME-03
	BID OPENING DATE	Tuesday, April 2, 2019 at 2:00 p.m. local time
ADDENDUM MUST BE SIGNED AND INCLUDED IN YOUR RESPONSE TO THE RFB.		

REVISIONS:

1. Replace page 2-1.4 of the RFB documents with revised page 2-1.4R provided with this Addendum. Revision was made to paragraph 19 of the Instructions to Bidders on how to price materials subject to sales taxes.
2. Replace page 4-3.23 of the RFB documents with revised page 4-3.23R provided with this Addendum. Revision includes replacing the word “average” with “peak” when referring to flow interruption, under 3.4 Flow Interruption; item “D”.
3. Replace the Construction Plan drawings included in the RFB documents with the revised Construction Plan provided with this Addendum through the following link: [Jester's Creek E. Outfall Replacement – PH 1 Drawings](#). Revisions were made to the following drawings only:

Drawing No.	Sheet No.
S-1	2
P-2	6
P-3	7
P-5	9
P-6	10
P-7	11
ES-2	16

QUESTIONS:

1. Do you have a construction cost/estimated budget?


Answer: Yes. CCWA's construction budget is \$8.5 million for the project. The budget includes contracted services, materials and construction management services.

2. Do you have Union Requirements?

Answer: No.

3. Can you provide an updated plan holders list?

Answer: The list is provided on pages 5 – 6 of this Addendum.

 <p>CLAYTON COUNTY Water AUTHORITY</p> <p>1600 Battle Creek Road, Morrow, GA 30260</p>	Jesters Creek East Outfall Replacement - Phase 1	
	ADDENDUM 1	
	DATE	March 26, 2019
	BID NUMBER	2019-PME-03
	BID OPENING DATE	Tuesday, April 2, 2019 at 2:00 p.m. local time
ADDENDUM MUST BE SIGNED AND INCLUDED IN YOUR RESPONSE TO THE RFB.		

4. **The existing timber retaining wall near Proposed Manhole 4 is partially rotted. How will replacement be paid for if excavation in proximity undermines this wall?**

Answer: Should excavation in proximity of the existing timber retaining wall undermine the wall and replacement is required, the replacement will be paid from Unforeseen Existing Conditions Allowance No. 1.

5. **Is the 48" open cut casing material by the Owner or Contractor?**

Answer: The 48" open cut casing material will be provided by CCWA.

6. **What is +/-INV OUT elevation for Proposed MH 15?**

Answer: Refer to Revision No. 3 of this Addendum.

7. **Sheet #10, is Secondary I a Proposed MH?**

Answer: Refer to Revision No. 3 of this Addendum.

8. **Sheet #10, can the callout for Proposed Secondary MH L be provided that is covered up by Double Row Type C Silt Fence callout?**

Answer: Refer to Revision No. 3 of this Addendum.


9. **Sheet #10, there are two (2) each Secondary MH Ms (STA 79+65.08, STA 84+35.34). Please advise if either of these secondary manholes will be relabeled.**

Answer: Refer to Revision No. 3 of this Addendum.

10. **Can Staging Area #4, Jester's Creek Trail Entry, be cleared to the limits of disturbance?**

Answer: Yes.

11. **It is our understanding that the average flow rates provided in Div 4, 3.4, D. are all that need to be considered when sizing bypass flow systems and that no peak flow factor needs to be considered despite Div 4, 3.4, E. 3. Indicating**

 <p>CLAYTON COUNTY Water AUTHORITY</p> <p>1600 Battle Creek Road, Morrow, GA 30260</p>	Jesters Creek East Outfall Replacement - Phase 1	
	ADDENDUM 1	
	DATE	March 26, 2019
	BID NUMBER	2019-PME-03
	BID OPENING DATE	Tuesday, April 2, 2019 at 2:00 p.m. local time
ADDENDUM MUST BE SIGNED AND INCLUDED IN YOUR RESPONSE TO THE RFB.		

that “pumping capacity shall be capable of handling peak flows” which appear not to be provided. Please advise.

Answer: Refer to Revision No. 2 of this Addendum.

- 12. Is proposed temporary doghouse MH paid for under secondary 6’ diameter riser or a different pay item?**

Answer: Yes, the Proposed Temporary Doghouse MH is paid from the Secondary 6’ Diameter Manhole Installation Riser Pay Item.

- 13. Is apartment trash disposal, tire disposal, etc. in the limits of disturbance the Contractor’s responsibility?**

Answer: Yes.

- 14. Please confirm that the intent is to clean and assess the CIPP option prior to performing CIPP design?**


Answer: The intent is to clean and assess the existing pipe prior to performing a CIPP design.

- 15. It appears that we will need to include removal/reinstallation of the trail call box/light poles. Are these items wired from buried services or stand-alone cellular or solar-powered without consideration for buried wiring replacement?**

Answer: CCWA understands the trail call box/light poles are stand-alone cellular or solar-powered.

- 16. Please confirm that the paved trail will be closed for the duration of the work and that replacement of this trail is included in Bid Item #12, Asphalt Placement.**

Answer: The paved trail will be closed to the public for the duration of the work in that area. The replacement of the trail is included in Bid Item #12, Asphalt Placement.

 <p>CLAYTON COUNTY Water AUTHORITY</p> <p>1600 Battle Creek Road, Morrow, GA 30260</p>	Jesters Creek East Outfall Replacement - Phase 1	
	ADDENDUM 1	
	DATE	March 26, 2019
	BID NUMBER	2019-PME-03
	BID OPENING DATE	Tuesday, April 2, 2019 at 2:00 p.m. local time
ADDENDUM MUST BE SIGNED AND INCLUDED IN YOUR RESPONSE TO THE RFB.		

- 17. Are we to include sales tax with any of the Contractor purchased materials, including manholes, stone bedding, concrete, grouting for Cased Crossings, etc.?**

Answer: Refer to Revision No. 1 of this Addendum.

- 18. How many copies of GEFA forms are required to be submitted with the bid?**

Answer: All completed GEFA forms must be submitted with each original and copy of the completed bid form submitted.

- 19. Can copies of the sign-in sheets for the pre-bid meeting be provided?**

Answer: Sign-in-sheets are provided on pages 7 – 10 of this Addendum.

<i>Acknowledgment of receipt of this addendum must be signed and included in your bid response.</i>	
COMPANY NAME	
SIGNATURE	
DATE	



1600 Battle Creek Road, Morrow, GA 30260

Jesters Creek East Outfall Replacement - Phase 1

ADDENDUM 1

DATE	March 26, 2019
BID NUMBER	2019-PME-03
BID OPENING DATE	Tuesday, April 2, 2019 at 2:00 p.m. local time

ADDENDUM MUST BE SIGNED AND INCLUDED IN YOUR RESPONSE TO THE RFB.

JESTER'S CREEK OUTFALL REPLACEMENT - PHASE 1 - VENDOR LIST

Company Name	Address	City, ST, Zip	Contact email address
ADC & Associates, Inc.	5396 Hillside Dr. Ste. E	Forest Park	belliott@adcandassociates.com
Advanced Drainage systems, Inc.			Catherine.Kiever@ads-pipe.com
AllSouth Construction, Inc.	9124 North Park Drive	Covington, Ga. 30014	ibbellsouth@bellsouth.net
American Contractors Grading and Paving, Inc.			tim@amcontractors.net
American Pipe			imccullough@american-usa.com
Astra Group Inc.	1611 Perry Blvd	Atlanta, GA 30318	clone@astragroupinc.com
Ballard MC			colin.braun@BallardMC.com
BHF Technology	P.O. Box 110143	Atlanta, GA 30311	trenchless@bhfttech.com
Brent Scarbrough & Company Inc.	155 Robinson Drive	Fayetteville, Ga. 30214	info@brent.us
Brown Electrical Services			brownelectricalservices@gmail.com
BRTU Construction, Inc.	2920 Campbellton Rd.	Atlanta	sint@brtuconstruction.com
Cajenn Construction & Rehabilitation Services, Inc.	2070 A. Cheshire Bridge Rd.	Atlanta	cristy@cajenn.com
Cantsink of Atlanta			ryan@cantsink.com
Celebrity Fence Co., Inc.			cfc@cs.com
CHARTER CONSTRUCTION SERVICES, INC.			kay@chartercs.com
Cheoah Construction			jimmas2@gmail.com
Civil Works			sharukh@civilworks.us
CJ HEARNE CONSTRUCTION			cjhearneconst@bellsouth.net
Classic City Utility, Inc.	1099 Boulevard SE	Atlanta	mikeclasscity@yahoo.com
Cleveland Carter Enterprises, Inc	5396 Hillside Drive	Forest Park	admin@cceatlanta.com
ConstructConnect	30 Technology Parkway South Sui	Norcross, GA 30092	gwen.tanehal@ConstructConnect.com
CTC Construction, LLC	127 Richardson Street	Atlanta	greg@ctcconstruct.com
Development Site Services Inc.	475 Swanson Road, P.O. Box 1145	Tyrone, GA 30290	lgreen@developmentsiteservices.com
Dodge Data & Analytics		Atlanta, GA	kathy.conrad@construction.com
Double P Grading Inc.			Eddie@doublepergradinginc.com
Eagle Excavation Inc.	4369 Tanners Church Rd.	Ellenwood, Ga. 30294	al@eagleexc.com
Foley Products Company	208 Jefferson Street	Newnan, GA 30263	bmeier@foleyproducts.com
Frankie Thompson Enterprises, Inc.	1292 Jimson Circle SE	Conyers	frankie@frankiethompson.com
Garney Construction	5895 Shiloh Road, Suite 114	Alpharetta, GA 30005	emalvin@garney.com
Georgia Development Partners			MMelton@gdpbuilds.com
Gibsons Grouting			dbolev@gibsonsgROUTING.com
GS Construction, Inc.			Awsalvo@gsconstruction.net
Hall Construction	670 Hall Road	Hampton, Ga. 30228	Hallconst1@aol.com
Haren Construction Company, Inc.		Etowah, TN 37331	sdrumright@harenconstruction.com
Insituform Technologies	1410 Gould Blvd	LaVergne, TN 37086	RMiller@aegion.com
Integrated Construction Management, Inc.	2260-F Lithonia Industrial Blvd.	Lithonia	sque@icmworks.net
isec Engineering			cwright@ISEC.engineering
J. G. Leone Enterprises, Inc.			igel@jgleone.com
John D Stephens, Inc.	272 Hurricane Shoals Rd, NE	Lawrenceville, GA 300146	Hmerrill@johndstephens.com
K.M. Davis Contracting Co., Inc.	3259 Austel Rd	Marietta, GA 30008-6835	montebaslev@bellsouth.net
Kemi Construction Co., Inc.	2550 W. Point Ave.	College Park	yakinnelu@kemiconstruction.com
Ken Blair			kwblair@aol.com
Kiewit			Don.Dohalloway@kiewit.com
L.T. & Associates, LLC	4011 Herron Pass, SW	Atlanta	ltandassociates@bellsouth.net



1600 Battle Creek Road, Morrow, GA 30260

Jesters Creek East Outfall Replacement - Phase 1


ADDENDUM 1

DATE	March 26, 2019
BID NUMBER	2019-PME-03
BID OPENING DATE	Tuesday, April 2, 2019 at 2:00 p.m. local time

ADDENDUM MUST BE SIGNED AND INCLUDED IN YOUR RESPONSE TO THE RFB.

JESTER'S CREEK OUTFALL REPLACEMENT - PHASE 1 - VENDOR LIST

Company Name	Address	City, ST, Zip	Contact email address
Layne Heavy Civil	300 E. Broad Street	Fairburn, GA 30213	tim.dunn@layne.com
Legacy Water Group, LLC			iklebowski@legacywatergroup.com
Lewis Contracting Services, LLC	457 Flat Shoals Ave. ste 2	Atlanta	jlewis@lewiscontractingservices.com
McIntyre Fencing Co.			linda@mcintyrefence.com
Metals & Materials Engineers, LLC	4130 Shirley Drive	Atlanta	bbennett@mmelab.com
MHR International, Inc.	1075 Peachtree St. NE Ste. 3650	Atlanta	mross@mhrinternational.com
Mid-South Builders, Inc.	P.O. Box 878	Lithonia	
Moorhead Construction	1513 Anderson St	Belton, SC 29627	office@moorheadconstruction.com
Morgan Contracting, Inc.	916 Katherine Avenue	Knoxville, TN 37921	tbayles@morgan1.com
Multi-Energy Group, LLC	1924 Lenox Road, NE	Atlanta	jshollis@multienergygroup.com
North Georgia Pipeline, Inc.		Dahlonega, Ga. 30533	sperry@northgeorgiaconcrete.com
North Georgia Pipeline, Inc.	85 Chestatee Industrial Park Dr.	Dahlonega, GA 30533	SPerry@northgeorgiaconcrete.com
Oldcastle Precast			Bill.Meier@oldcastle.com
R2T, Inc.	303 Perimeter Center N, Suite 300	Atlanta	kim.ajy@r2tinc.com
Rain For Rent			ktinnerman@rainforrent.com
RAM Jack USA			arthur@ramjackusa.com
RDJE, Inc.	679 Hwy 29 South, Suite A	Newnan, GA 30263	EShipley@RDJElnc.com
Reeves & Young, LLC	4000 Smithtown Rd. Suite 200	Suwanee, GA 30024	dwelch@reevesyoung.com
Reynolds Construction	300 East Broad Street	Fairburn, GA 30213	sandra.murphy@reynoldson.com
Rockdale Pipeline Inc.	P.O. Box 1157	Conyers, Ga. 30012	srcooley@rockdalepipeline.com
Ruby-Collins, Inc.	4806 Wright Dr.	Smyrna, GA 30082	scdine@ruby-collins.com
Russo Corporation			ivaughn@russocorp.com
Site Engineering, Inc.	7025 Best Friend Rd	Atlanta, GA 30340	tamara@siteengineeringinc.com
SoCo Contracting Company, Inc.	3175 Presidential Drive	Atlanta, Georgia 30340	mioell@soco-contracting.com
SoilTek	P.O. Box 1918	Flowery Branch, GA 30542	ahare@soiltekga.com
Sol Construction, LLC	4120 Presidential Pkwy. Ste. 115	Atlanta	jgomez@solconstructionllc.com
Stephen Industries			cclark@stephensmds.com
Strack Inc.	125 Laser Industrial Court	Fairburn, Ga. 30213	jasonr@strackinc.com
Sunbelt Rentals			kebin.friel@sunbeltrentals.com
Swing Construction Company, Inc.	3189 Oxbridge Way	Lithonia	swingco@gmail.com
TGS Construction Services	313 Worthington Lane	McDonough, GA 30253	tsgno@yahoo.com
The Blue Book Building & Construction Network			vbifulco@mail.thebluebook.com
The Corbett Group, LLC	7667 McKay Industrial	Drive Douglasville, GA 30134	mcorbett@thecorbettgroup.net
The Renee Group			Ajefferson@TheReneeGroup.com
Thompson Pipe Group			aboer@thompsonpipegroup.com
Thomson Pump			kkrause@thompsonpump.com
Thrasher Contracting, LLC	1500 Marietta Road	Atlanta, GA	mthrasher@thrashertrucking.com
United Grading & Excavating	199-A Fairburn Industrial Blvd.	Fairburn, Georgia 30213	cmatticola@unitedgrading.com
Unity Construction Co., Inc.	3941 Flint Hill Road	Powder Springs, GA 30127	alanunity@bellsouth.net
Value Jetting Sewer & Drain	P.O. Box 547	Conley	valuejetting@bellsouth.net
Wayne Davis Concrete			JMinter@waynedavisconcrete.com
YAH Group, LLC	1077 4th Street, Unit 1	Stone Mountain	victorkuma@live.com

 <p>CLAYTON COUNTY Water AUTHORITY</p> <p>1600 Battle Creek Road, Morrow, GA 30260</p>	Jesters Creek East Outfall Replacement - Phase 1	
	ADDENDUM 1	
	DATE	March 26, 2019
	BID NUMBER	2019-PME-03
	BID OPENING DATE	Tuesday, April 2, 2019 at 2:00 p.m. local time
ADDENDUM MUST BE SIGNED AND INCLUDED IN YOUR RESPONSE TO THE RFB.		

Clayton County Water Authority

Non-Mandatory Pre-Bid Meeting and Site Visit

Wednesday, March 13, 2019 at 2:00 P.M. (local time)

Department: PROGRAM MANAGEMENT & ENGINEERING

Bid Title: JESTER'S CREEK EAST OUTFALL REPLACEMENT – PHASE 1

Bid Date and Time: Tuesday, April 2, 2019 at 2:00 P.M. (local time)

Page 1 of 4

COMPANY NAME	REPRESENTATIVE	PHONE NUMBER	EMAIL ADDRESS
Sunbelt Pump Solutions	Kevin Friel	404 557-7377	kevin.friel@sunbeltrentals.com
Civil Works	Sharukh Mohammed	361-960-3567	sharukh@civilworks.us
NORTH GEORGIA PIPELINE	SUE PERRY	706-867-1774	SPERRY@NORTHGEORGIA CONCRETE.COM
CCWA	Kathy Bogaert	770-960-5223	ccwa_procurement@ccwa.us
CCWA	Hilda Flores	⊥	⊥
CCWA	Karen Riser	⊥	⊥
CCWA	Stan Court	⊥	⊥



1600 Battle Creek Road, Morrow, GA 30260

Jesters Creek East Outfall Replacement - Phase 1

ADDENDUM 1

DATE	March 26, 2019
BID NUMBER	2019-PME-03
BID OPENING DATE	Tuesday, April 2, 2019 at 2:00 p.m. local time

ADDENDUM MUST BE SIGNED AND INCLUDED IN YOUR RESPONSE TO THE RFB.

Clayton County Water Authority

Non-Mandatory Pre-Bid Meeting and Site Visit

Wednesday, March 13, 2019 at 2:00 P.M. (local time)


Department: PROGRAM MANAGEMENT & ENGINEERING

Bid Title: JESTER'S CREEK EAST OUTFALL REPLACEMENT - PHASE 1

Bid Date and Time: Tuesday, April 2, 2019 at 2:00 P.M. (local time)

Page 2 of 4

COMPANY NAME	REPRESENTATIVE	PHONE NUMBER	EMAIL ADDRESS
Reynolds	Craig Wiley	678 898 7235	Craig.Wiley@reynoldscan.com
Reynolds	Matt Stonica	404-783-2750	Matthew.Stonica@Reynoldscan.com
JOHN D. STEPHENS	HANK MERRILL	770-972-8000	HMERRILL@JOHNDSTEPHENS.COM
Xylem Inc Godwin Pumps	Jay Andrade	404-569-7395	Jay.Andrade@xyleminc.com
CCWA	Keith Watkins	770-960-5223	ccwa_procurement@ccwa.us
CCWA	Clifford Benoset		
CCWA	Larry Michaels		
CCWA	Garfield Cousins		

 <p>CLAYTON COUNTY Water AUTHORITY</p> <p>1600 Battle Creek Road, Morrow, GA 30260</p>	Jesters Creek East Outfall Replacement - Phase 1	
	ADDENDUM 1	
	DATE	March 26, 2019
	BID NUMBER	2019-PME-03
	BID OPENING DATE	Tuesday, April 2, 2019 at 2:00 p.m. local time
ADDENDUM MUST BE SIGNED AND INCLUDED IN YOUR RESPONSE TO THE RFB.		

Clayton County Water Authority

Non-Mandatory Pre-Bid Meeting and Site Visit

Wednesday, March 13, 2019 at 2:00 P.M. (local time)

Department: PROGRAM MANAGEMENT & ENGINEERING

Bid Title: JESTER'S CREEK EAST OUTFALL REPLACEMENT – PHASE 1

Bid Date and Time: Tuesday, April 2, 2019 at 2:00 P.M. (local time)

Page 3 of 4

COMPANY NAME	REPRESENTATIVE	PHONE NUMBER	EMAIL ADDRESS
Kiewit	John Krupilis	574-338-0004	John.Krupilis@Kiewit.com
Rocketdate Pipeline	Richard Duncan	770-922-4123 678-614-4729	rduncan@rocketdatepipeline.com
Oshobar Hardman	GEFA	470-626-7036	
FEDERAL EC LLC	JONATHAN RAYMER	770-616-7523	jraymer@federalec.com



1600 Battle Creek Road, Morrow, GA 30260

Jesters Creek East Outfall Replacement - Phase 1

ADDENDUM 1

DATE	March 26, 2019
BID NUMBER	2019-PME-03
BID OPENING DATE	Tuesday, April 2, 2019 at 2:00 p.m. local time

ADDENDUM MUST BE SIGNED AND INCLUDED IN YOUR RESPONSE TO THE RFB.

Clayton County Water Authority

Non-Mandatory Pre-Bid Meeting and Site Visit

Wednesday, March 13, 2019 at 2:00 P.M. (local time)

Department: PROGRAM MANAGEMENT & ENGINEERING

Bid Title: JESTER'S CREEK EAST OUTFALL REPLACEMENT - PHASE 1

Bid Date and Time: Tuesday, April 2, 2019 at 2:00 P.M. (local time)

Page 4 of 4

COMPANY NAME	REPRESENTATIVE	PHONE NUMBER	EMAIL ADDRESS
VLW GROUP LLC	Valister Wilson CANA Mungin	678-922-2480	valister@vlwgroupllc.com
Rain for Rent	Kenneth Timmerman	404-670-6099	ktimmerman@rainforrent.com
Gordy Construction	Schley Gordy	706-324-0143	schley@gordyconstruction.com
Ruby Collins	MONTY BEASLEY	478-515-4271	mbeasley@rubycollins.com

Division 2

Bid Requirements

Section 1: Instructions to Bidders

- may disqualify the bid. Bidders are required to inform themselves fully as to the availability of materials and the conditions relating to construction and labor under which any work will be or is now being performed. No error or misjudgment nor any lack of information on local conditions, general laws or regulations on the part of the Bidder shall merit withdrawal of the bid.
18. Copies of all communication pertaining to bids must be sent to the Contracts, Compliance and Risk Management Section.
 19. The purpose of this bid is to establish contract prices. Unit price extension and net total must be shown if applicable. Cash discounts should be indicated separately. Any applicable sales taxes should be included in the unit prices for all materials to be provided by the successful Bidder.
 20. Bidders are hereby notified and agree by submission of a Bid Form that if additional items not listed in the Bid Form become necessary and require unit prices not established by the Bid Form, the unit prices of such items shall be negotiated and shall be directly proportional to the established unit prices of similar items in the Bid Form.
 21. All prices on goods shall be for delivery, our destination, f.o.b. freight prepaid Jonesboro, Georgia, and/or Morrow, Georgia, unless otherwise shown. Any deliveries shall be made as needed and requested throughout the contract period.
 22. Quantities when shown are estimates only, based on anticipated needs. The CCWA reserves the right to purchase more or less based on actual need at contract price. If a Bidder intends to offer minimum or maximum shipment quantities, such intent and such quantities should be specified on the Bid Form. Otherwise, none will be assumed.
 23. The time for completion of the work is stated in the Bid Form. Failure to complete the work within this period shall result in payment to the CCWA of liquidated damages in an amount provided for by contract for each calendar day in excess of the Contract time.
 24. The Bidder must employ such methods and means in carrying out the work as will not cause any interruption of or interference with any other Contractor.
 25. The successful Bidder must comply with the applicable Risk Management Requirements prior to beginning performance, and during the contract period.

Division 4

Specifications

Section 3: Construction Standards

3.4 Flow Interruption (Revised)

- A. A flow interruption plan shall be submitted for CCWA review and approval.
- B. No excavation activities shall commence until a flow interruption plan is approved by CCWA.
- C. Flow interruption may be completed using plugging and/or bypass pumping methods. Use upstream manholes for bypass pumping. Newly installed 36" sanitary sewer segments (manhole to manhole) may receive flow as soon as all testing is completed and accepted.
- D. The following list provides **peak** flows that are to be considered when planning flow interruption.
 - 1. 36" Outfall at Station 3+75 at Existing MH 3: 9,100 gpm
 - 2. 36" Outfall at Station 27+56.38 at Existing MH 8: 9,100 gpm
 - 3. 36" Outfall at Station 55+92.37 at Existing MH 16: 8,400 gpm
 - 4. 36" Outfall upstream of Station 89+60.20: 8,400 gpm
 - 5. 8" Service Connection (Tie-In No. 1): 100 gpm
 - 6. 6" Service Connection (A): 100 gpm
 - 7. 8" Service Connection (B): 300 gpm
 - 8. 8" Service Connection (C): 300 gpm
 - 9. 8" Service Connection (D): 100 gpm
 - 10. 8" Service Connection (E): 100 gpm
 - 11. 6" Service Connection (Existing MH 8): minimal
 - 12. 8" Service Connection (F): 300 gpm
 - 13. 8" Service Connection (G): 100 gpm
 - 14. 12" Service Connection (H): 1,000 gpm
 - 15. 8" Service Connection (I): 100 gpm
 - 16. 4" Service Connection (J): minimal
 - 17. 8" Service Connection (K): 100 gpm
 - 18. 8" Service Connection (L): 300 gpm
 - 19. 6" Service Connection (M): minimal
 - 20. 8" Service Connection (N): 500 gpm
 - 21. 8" Service Connection (O): 300 gpm
 - 22. 8" Service Connection (P): 300 gpm
 - 23. 8" Service Connection (Q): 100 gpm
 - 24. 8" Service Connection (R): 100 gpm