



ADDENDUM #1

COUNTY ROAD 12 STORMWATER CHANNEL IMPROVEMENTS ENGR-070820

JUNE 6, 2020

Addendum #1 is being issued to correct a contradiction to the rock base thickness noted on the unit cost sheet verses the drawings. Addendum #1 changes the drawing sections to match the unit cost sheet.

Original drawings Dwg-02 and DWG-03 state the base thickness shall be 6". The attached drawings (Revision 1) reflect the change of the base thickness from 6" to 4".

Also, a request for clarification of concrete bid specs has been received. The concrete specs call out for 3000 psi at 28 days. Regular 3000 psi exterior is acceptable.

Please acknowledge receipt of Addendum #1 on page 3 of the bid packet when submitting your bid.

Rachel Keith
Project Manger
City of Foley