

**ADDENDUM NUMBER ONE
TO
2018 CITY-WIDE SEWER IMPROVEMENTS
CITY OF WHITE HOUSE, TENNESSEE**

This is Addendum Number One (1) issued this the 2nd day of May 2018 to all parties who hold a set of Bid Documents, and therefore are eligible to bid on the above named project. Each Bidder shall acknowledge receipt of the Addendum on the Bid and shall incorporate all changes in the Bid. This addendum consists of one (1) pages.

CLARIFICATIONS:

AGREEMENT BETWEEN OWNER AND CONTRACTOR FOR CONSTRUCTION CONTRACT

The Unit Price Work will be inserted into the Agreement at the time of contract. For bidding purposes, Bidder shall only consider the Bid Form for Construction Contracts. The Bid form includes 19 Bid Items.

MODIFICATIONS:

SECTION 01200 MEASUREMENT AND PAYMENT

BID ITEM 7: 12-INCH INSERTA ~~TEE~~ VALVE AND BOX

Work included under this line item of payment shall include furnishing and installing a 12-inch Inserta ~~TEE~~ Valve (or approved equal) as indicated on the drawings. The unit price bid shall include all costs for excavation, valve, materials, valve box, backfill and compaction, compaction, and site restoration. Payment will be made at the unit price bid for the actual number and type of valve installed.

SECTION 01200 MEASUREMENT AND PAYMENT

BID ITEM 16 FLOW METER WITH VAULT

Add the following paragraph after paragraph 1 of Bid Item 16:

The Flow Meters shall be installed at each of the pump station locations. The Flow Meter at the Granda Flora location is an 8-inch, and the Flow Meter at the No. Palmer's Chapel location is a 12-inch.

This Addendum Number One (1) is issued this the 2st day of May 2018.

Cynthia Wheeler, P.E.
City of White House
105 College Street
White House, Tennessee

