

**ADDENDUM NUMBER THREE  
TO  
2018 CITY-WIDE SEWER IMPROVEMENTS  
CITY OF WHITE HOUSE, TENNESSEE**

This is Addendum Number Three (3) issued this the 4<sup>rd</sup> day of May 2018 to all parties who hold a set of Bid Documents, and therefore are eligible to bid on the above named project. Each Bidder shall acknowledge receipt of the Addendum on the Bid and shall incorporate all changes in the Bid. This addendum consists of one (1) page.

**CLARIFICATIONS:**

All Ductile Iron fittings and pipe shall be lined with Protecto 401.

**MODIFICATIONS:**

Plans Sheets

For all references to 12-inch force main, Sheet C-201, C-202, and C-203, delete DR 26 and replace with “DR 21”.

This Addendum Number Three (3) is issued this the 4<sup>rd</sup> day of May 2018.

Cynthia Wheeler, P.E.  
City of White House  
105 College Street  
White House, Tennessee

