

CITY OF GRIFFIN
SHOAL CREEK NEW HEADWORKS AND PUMP STATION

FROM: PARAGON CONSULTING GROUP, INC.
118 NORTH EXPRESSWAY
GRIFFIN, GA 30223

TO: ALL BIDDERS OF RECORD

RE: Addendum No. 3, dated September 13, 2018

This Addendum forms a part of the Contract Documents and modifies the original Bidding Documents dated August 2018.

This Addendum consists of two (2) pages, one supplemental drawing, and one (1) specification section.

CONTRACT DOCUMENTS AND SPECIFICATIONS

- Add. 3.1 Modification: Supplemental Drawing SD4 is included with this Addendum and becomes a part of the Contract Documents. The pad detail shown on SD4 is meant to replace the 12' x 20' HDPE liner pad shown in Polishing Pond No. 1.
- Add. 3.2 Modification: A new specification section, PARKSON AWP10-5.0 AQUA WASHPRESS, is included with this Addendum and becomes a part of the Contract Documents.
- Add. 3.3 Clarification: The Contractor should include pricing for aluminum handrails around the perimeter of the Headworks structure in the Project Base Construction Cost.

Add. 3.4 Clarification: Plan Sheet S-201, HEADWORKS SECTIONS, the 6-inch thick piece of concrete at ELEV 796.80 is a table in the grit chamber located above the entrance from the coanda ramp. The width of this concrete varies due to the curvature of the grit chamber. The photo below is intended to illustrate the structure for further clarification.



End of Addendum No. 3