



St. Johns River Water Management District

Michael A. Register, P.E., Executive Director

525 Community College Parkway S.E. • Palm Bay, FL 32909 • 321-984-4940 • www.sjrwmd.com

DATE: January 24, 2023

TO: Prospective Respondents

FROM: Amy Lucey, Procurement Specialist

SUBJECT: Addendum #1 to Invitation for Bid, # 38345-1, Limerock Purchase and Delivery for Lake Apopka North Shore.

As a result of inquiries, the following clarifications/changes are provided for your information. Please make all appropriate changes to your bid documents. Note: changes are reflected with original language shown with strike-through and new language is underlined.

Q1: Is FDOT-certified Shell Rock acceptable as a replacement for Lime Rock?

A1: Yes, FDOT-certified Shell Rock is acceptable.

NOTE: The Bid Due Date remains 2:00 p.m., **Thursday February 9, 2023**

Please acknowledge receipt of this Addendum on the Bid FORM provided in the proposal package.

If you have any questions, please e-mail me at alucey@sjrwmd.com.