



LED Street Light Replacement Project #1916 ADDENDUM I Answers to Questions

1. What type of LED luminaires are you requesting and the exact specifications (watt, kelvin, lumen) of those luminaires?

The City will provide all materials (luminaires, arms, hardware, etc.). Bidders shall provide bucket trucks and personnel qualified to perform work at secondary (less than 600 volts) voltage levels.

2. Would you be willing to accept just having 1 bucket truck working on it full time? It would be hard for me to keep 2 on it. Additionally, what are the height of the lights? 14-16' or 25'?

If that is all you can provide, please state so in the bid. If all other things are equal, we might give preference to someone who can keep 2 trucks on the project, but if one is all you can bid, please do so.

Lights will range in height. We do have a few that are as high as 35' on fiberglass poles, but the vast majority are no higher than 25'.