

BID 0084-UCHS ROOF

ADDENDUM 1

1. What type of roofing membrane will be used?
 - a. The new roof system will be an EPDM membrane.
2. Who is the roof manufacturer?
 - a. We have 4 manufacturers specified to choose from:
 - i. Firestone
 - ii. Carlisle
 - iii. GenFlex
 - iv. Versico